

Math 035
Math 035 me

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No. 14/39-28

State Permit No. _____

(1) OWNER:
Name Charles Reddick
Address Ironside Oregon

(2) LOCATION OF WELL:
County MALHEUR Driller's well number _____
1/4 Section 38 T. 114S R. 39E W.M.
Bearing and distance from section or subdivision corner
IRONSIDE MEET STORE
50' NORTH of HIGHWAY 26

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL: Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED: Threaded Welded
10" Diam. from -1 ft. to 170 ft. Gage 4"
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used none
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS: Well screen installed Yes No
Manufacturer's Name _____ Model No. _____
Slot size _____ ft. to _____ ft.
Diam. Slot size _____ ft. to _____ ft.

(9) CONSTRUCTION: Well seal—Material used in seal BENTONITE
Depth of seal 36 ft. Was a packer used? SAND
Diameter of well bore to bottom of seal 12" in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS: Static level 26 ft. below land surface Date 4-25-63
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
" " " " " "
Bailer test 60 gal./min. with 124 ft. drawdown after 2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 68° Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 9 3/4"
Depth drilled 207 ft. Depth of completed well 205 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
SOIL SANDY	0	4
CLAY	4	32
GRAVEL + SAND SOME WATER	32	53
CLAY BROWN	53	55
CLAY + GRAVEL	55	195
SAND FINE WATER	195	197
CLAY yellow	197	205
GRAVEL MEDIUM WATER	205	207

Work started 4-15 1963 Completed 4-25 1963
Date well drilling machine moved off of well 4-25 1963

(13) PUMP: Manufacturer's Name NO PUMP YET
Type: _____

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Holloway Drilling Co.
(Person, firm or corporation) (Type or print)
Address Ontario Oregon
Drilling Machine Operator's License No. 202
[Signed] May Holloway
(Water Well Contractor)
Contractor's License No. 16 Date 5-6, 1963