

NC

Math 038

Math 038

A

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

STATE OF OREGON (Please type or print)

G-3975

State Well No. 14/39-29

State Permit No.

(1) OWNER:

Name T. Ronside Cemetery Address T. Ronside, OREGON

(2) LOCATION OF WELL:

County MALHEUR Driller's well number SE 1/4 NE 1/4 Section 29 T. 14S R. 39E W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandonment []

Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 1 ft. to 40 ft. Gage 4

(7) PERFORATIONS:

Perforated? [] Yes [X] No Type of perforator used Size of perforations in. by in.

(8) SCREENS:

Well screen installed? [] Yes [X] No Manufacturer's Name Type Model No. n. Slot size Set from ft. to Diam. Slot size Set from ft. to

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Depth of seal 20 ft. Was a packer used? Cement Diameter of well bore to bottom of seal 10" in. Were any loose strata cemented-off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 38' ft. below land surface Date 4-8-67 Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [X] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Baller test 60 gal./min. with 15 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water 59° Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG: Diameter of well below casing 7 3/4

Depth drilled 120 ft. Depth of completed well 120' ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows: Soil 0' 3', CLAY with Boulders 3' 20', GRAVELLY CLAY 20' 35', SAND FINE SOME WATER 35' 37', CLAY BLUE 37' 117', SAND COARSE WATER 117' 120'

Work started 4-6 1967 Completed 4-8 1967 Date well drilling machine moved off of well 4-8-1967

(13) PUMP:

Manufacturer's Name No PUMP yet Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Holloway Drilling Co (Person, firm or corporation) (Type or print) Address ONTARIO OREGON Drilling Machine Operator's License No. 101 [Signed] Max Holloway (Water Well Contractor) Contractor's License No. 16 Date 6-8 1967