

STATE OF OREGON  
**WATER WELL REPORT**  
 (as required by ORS 537.765)

*Malh*  
*395*

**RECEIVED**

*Malh*  
*395*

*17S/44E-23d*

JUL 28 1988

**(1) OWNER:** Owner's Well Number \_\_\_\_\_  
 Name David White  
 Address 4457 John Day hwy.  
 City Vale State Or. Zip \_\_\_\_\_

**(2) TYPE OF WORK:**  
 New Well  Deepen  Recondition  Abandon

**(3) DRILL METHOD:**  
 Rotary Air  Rotary Mud  Cable  Other

**(4) PROPOSED USE:**  
 Domestic  Community  Industrial  Irrigation  
 hermal  Injection  Other \_\_\_\_\_

**(5) BORE HOLE CONSTRUCTION:** 55 ft.  
 Depth of Completed Well \_\_\_\_\_ ft.  
 Special Standards date of approval \_\_\_\_\_

HOLE		SEAL		Amount		
meter	From	To	Material	From	To	sacks or pounds
16"	0	55	cement	0	18	17 sacks

How was seal placed? Method  A  B  C  D  E  
 Other \_\_\_\_\_

Backfill placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Material \_\_\_\_\_  
 Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Size of gravel \_\_\_\_\_

**(6) CASING/LINER:**

Casing:	Diameter	From	To	Gauge	Steel		Plastic		Welded Threaded	
					✓	□	✓	□	□	□
	12	+1	55	#160	□	□	✓	□	□	□

Liner: \_\_\_\_\_

Location of shoe(s) \_\_\_\_\_

**(7) PERFORATIONS/SCREENS:**

Perforations Method \_\_\_\_\_  
 Screens Type \_\_\_\_\_ Material \_\_\_\_\_

W	To	Slot size	Number	Diameter	Tele/pipe size	Casing	Liner
20	55	1/8	180			✓	□

**(8) WELL TESTS: Minimum testing time is 1 hour**

Yield gal/min	Pumping level	Drill stem at	Time 1/2 hr
1225	32		
225	32		1 hr

Temperature of water 59° Depth Artesian Flow Found \_\_\_\_\_  
 Was a water analysis done  No  Yes By whom \_\_\_\_\_  
 Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other \_\_\_\_\_  
 Depth of strata: 30

**(9) LOCATION OF WELL by legal description:**  
 County Malhuen Latitude \_\_\_\_\_ Longitude \_\_\_\_\_  
 Township 17 N or S, Range 44 E or W, WM.  
 Section 23 S.E. 1/4 S.W. 1/4  
 Tax Lot 890 Lot \_\_\_\_\_ Block \_\_\_\_\_ Subdivision \_\_\_\_\_  
 Street Address of Well (or nearest address) \_\_\_\_\_

**(10) STATIC WATER LEVEL:**  
 \_\_\_\_\_ ft. below land surface. Date 6-22-88  
 Artesian pressure \_\_\_\_\_ lb. per square inch. Date \_\_\_\_\_

**(11) WELL LOG:** Ground elevation \_\_\_\_\_

Material	From	To	WB?	SWL
Soil	0	3		
Brn. clay	3	12		
Brn. clay (sandy)	12	20	x	3
Brn. & blk. gravel (med.)				
brn. sand (fine)	20	29	x	3
Brn. clay med. brn. sand	29	55	x	3

Date started 6-22-88 Completed 6-28-88

**(unbonded) Water Well Constructor Certification:**  
 I constructed this well in compliance with Oregon well construction standards. Materials used and information reported above are true to my best knowledge and belief.

Signed \_\_\_\_\_ Date \_\_\_\_\_

**(bonded) Water Well Constructor Certification:**  
 I accept responsibility for construction of this well and its compliance with all Oregon water well standards. This report is true to the best of my knowledge and belief.

Signed Herbert H. Bowman Date 7-26-88

Company Bowman Drilling Co. Job No. \_\_\_\_\_