

STATE OF OREGON WATER SUPPLY WELL REPORT

MALH 54801

WELL I.D. LABEL# L 151523 START CARD # 1075123 ORIGINAL LOG #

9/18/2024

(as required by ORS 537.545 & 537.765 and OAR 690-205-0210)

(1) LAND OWNER Owner Well I.D. First Name Last Name Company FRY FOODS INC Address 602 STANTON BLVD City ONTARIO State OR Zip 97914

(2) TYPE OF WORK [X] New Well [] Deepening [] Conversion [] Alteration (complete 2a & 10) [] Abandonment (complete 5a)

(2a) PRE-ALTERATION Dia + From To Gauge Stl Plstc Wld Thrd Casing: Seal:

(3) DRILL METHOD [] Rotary Air [] Rotary Mud [X] Cable [] Auger [] Cable Mud [] Reverse Rotary [] Other

(4) PROPOSED USE [] Domestic [] Irrigation [] Community [X] Industrial/ Commercial [] Livestock [] Dewatering [] Thermal [] Injection [] Other

(5) BORE HOLE CONSTRUCTION Special Standard [] (Attach copy) Depth of Completed Well 75.00 ft.

Table with columns: Dia, From, To, Material, From, To, Amt, sacks/lbs. Rows include Bentonite Chips and Calculated values.

Seal placement method [] A [] B [] C [] D [] E [X] Other: CHIP BENTONITE Backfill placed from 38 ft. to 61 ft. Material SILICA SAND Size 8/12

(5a) ABANDONMENT USING UNHYDRATED BENTONITE Proposed Amount Actual Amount

(6) CASING/LINER Table with columns: C/L, Dia, From, To, Gauge, Mat. Type, Wld, Thrd, Shoe, Location. Rows show casing details.

Temp casing [X] Yes Dia 16 From + [X] 1 To 60

(7) PERFORATIONS/SCREENS Table with columns: Perf/ Screen, Casing/ Liner, Dia, From, To, Scrn/slot width, Slot length, # of slots, Tele/ Pipe size.

(8) WELL TESTS: Minimum testing time is 1 hour

Table with columns: Type of Test, Yield (gal/min), Drawdown, Drill Stem/ Pump Depth, Duration (hr). Row 1: Pump, 112, 13, 60, 1.

Temperature 64 °F Lab analysis [] Yes By Water quality concerns? [] Yes (describe below) TDS amount 296 ppm

(9) LOCATION OF WELL (legal description) County MALHEUR Twp 17.00 S N/S Range 46.00 E E/W WM Sec 13 NE 1/4 of the SE 1/4 Tax Lot 3300

(10) STATIC WATER LEVEL Date SWL(psi) + SWL(ft) Existing Well / Pre-Alteration Completed Well 9/13/2024 41

WATER BEARING ZONES Table with columns: SWL Date, From, To, Est Flow, SWL(psi), + SWL(ft). Row 1: 9/13/2024, 41, 60, 112, 41.

(11) WELL LOG Ground Elevation Table with columns: Material, From, To. Rows include soil, silty clay, hard pan, etc.

Construction Begin Date 9/9/2024 Begin Time 06 13 End Date 9/13/2024

(unbonded) Water Well Constructor Certification I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards.

(bonded) Water Well Constructor Certification I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above.

WATER SUPPLY WELL REPORT - Map with location identified must be attached and shall include an approximate scale and north arrow

MALH 54801

9/18/2024

Map of Hole

STATE OF OREGON WELL LOCATION MAP	Oregon Water Resources Department 725 Summer St NE, Salem OR 97301 (503)986-0900	
This map is supplemental to the WATER SUPPLY WELL REPORT		
LOCATION OF WELL	Well Label: 151523	
Latitude: 44.08679000 Datum: WGS84	Printed: September 18, 2024	
Longitude: -117.02548000	<small>DISCLAIMER: This map is intended to represent the approximate location the well. It is not intended to be construed as survey accurate in any manner.</small>	
Township/Range/Section/Quarter-Quarter Section: WM17.00S46.00E13NESE	<small>Provided by well constructor</small>	
Address of Well: 602 STANTON BLVD, ONTARIO, OR 97914		

