NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

RECEIVED DEC 31 1964 STATE ENGINEER SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

Mah 717

State Well No. 18/4E-16D

State Permit No.

(1) OWNER:
Name Roy C Stewart
Address Westfall Ore

(2) LOCATION OF WELL: Well # 3
County Malheur Driller's well number
NW ¼ NW ¼ Section 16 T. 18 R. 41 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☑ Other ☐

(5) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☑ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☐
12" Diam. from 0 ft. to 50 ft. Gage .025
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☐ No
Type of perforator used
Size of perforations 1/4 in. by 6 in.
200 perforations from 30 ft. to 50 ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal Concrete
Depth of seal 18 ft. Was a packer used?
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? ☐ Yes ☐ No Depth
Was a drive shoe used? ☐ Yes ☐ No
Was well gravel packed? ☐ Yes ☐ No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 17 ft. below land surface Date 12-24-64
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☑ Yes ☐ No If yes, by whom? Hysell
Yield: 480 gal./min. with 50 ft. drawdown after 2 hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG: Diameter of well below casing
Depth drilled ft. Depth of completed well ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Sandy Clay	0	25'
Sand & Gravel	25	50
Rock Hard	50	107

Work started 12-2 1964 Completed 12-24 1964
Date well drilling machine moved off of well 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Hysell Pump & Drill (Person, firm or corporation) (Type or print)
Address Box 351
Drilling Machine Operator's License No. 65
[Signed] [signature] (Water Well Contractor)
Contractor's License No. 396 Date 12-28, 1964

(USE ADDITIONAL SHEETS IF NECESSARY)