

The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL REPORT

STATE OF OREGON
(Please type or print)

State Well No. 18/41-1
State Permit No. C-4815

(1) OWNER:

Name Robert J. Ward
Address Harper, Oregon

(2) LOCATION OF WELL:

County Malheur Driller's well number SW ¼ NE ¼ Section 19 T. 18 S. R. 41 E. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐ Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Irrigation ☒ Test Well ☐ Other ☐ Dug ☐ Bored ☐

(6) CASING INSTALLED:

(6) CASING INSTALLED: Threaded ☐ Welded ☒
12 " Diam. from 0 ft. to 25 ft. Gage 1025
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

(7) PERFORATIONS:

Perforated? ☒ Yes ☐ No

Type of perforator used Sorck

Size of perforations 6 in. by 14 in.

40 perforations from ft. to 23 ft.

..... perforations from ft. to ft.

..... perforations from ft. to ft.

..... perforations from ft. to ft.

..... perforations from ft. to ft.

(8) SCREENS:

(8) SCREENS: Well screen installed? ☐ Yes ☒ No

Manufacturer's Name _____ Model No. _____

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement

Depth of seal 18 ft. Was a packer used? no

Diameter of well bore to bottom of seal 20 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth _____

Was a drive shoe used? ☒ Yes ☐ No

Was well gravel packed? ☐ Yes ☒ No Size of gravel: _____

Gravel placed from _____ ft. to _____ ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? _____ depth of strata _____

Method of sealing strata off _____

(10) WATER LEVELS:

Static level 2 ft. below land surface Date 3-5-67
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level.

Was a pump test made? ☒ Yes ☐ No If yes, by whom? J. J. Kelly Pump
Yield: 300 gal./min. with 27 ft. drawdown after 2 hrs.

Yield: 300 gal./min. with 27 ft. drawdown after 2 hrs

Bailer test	gal./min. with	ft. drawdown after	hrs
-------------	----------------	--------------------	-----

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG:

Diameter of well below casing 12

Depth drilled ~~33~~ 33 ft. Depth of completed well 25 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

[illegible]

Work started	3-3-	19 67	Completed	3-5-	19 67
Date well drilling machine moved off of well	3-6-	19 67			

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Hyse Pump & Drilling
(Person, firm or corporation) (Type or print)

Address 365 Main St. N - Vale, Oregon

Drilling Machine Operator's License No/ 65

[Signed] George Russell
(Water Well Contractor)

Contractor's License No. 396- Date 0, 19

(USE ADDITIONAL SHEETS IF NECESSARY)