NOTICE TO WATER WELL CONTRACTOR The original and first copy of this report are to be

filed with the

STATE ENGINEER, SALEM, OREGON 97310 UL 28 19/U (Please type or print) within 30 days from the date of well completion. STATE ENGINEER above this line)

State Permit No.

| SALEM ORGOVI | | |
|---|---|--|
| (1) OWNER: | (10) LOCATION OF WELL: | |
| Name Mr. & Mrs. Peter Threlkel | County Marion Driller's well number 445 | |
| Address Rte.1, Turner, Ore. | NY 14 SE 14 Section 23 T. 95 | R. 21 W.M. |
| (A) TYPE OF WORK (Abb). | Bearing and distance from section or subdivisi- | on corner |
| (2) TYPE OF WORK (check): | | |
| New Well □ Deepening ■ Reconditioning □ Abandon □ | | |
| If abandonment, describe material and procedure in Item 12. | (11) WATER LEVEL: Completed w | ell. |
| (3) TYPE OF WELL: (4) PROPOSED USE (check): | Depth at which water was first found | 32 ft. |
| Rotary ☐ Driven ☐ Domestic ☐ Industrial ☐ Municipal ☐ Cable ☐ Jetted ☐ | Static level 5 ft. below land s | urface. Date 7/24/70 |
| Cable | Artesian pressure lbs. per squar | e inch. Date |
| 75) CASING INSTALLED: Threaded □ Welded ₩ 8" Diam. from 0 ft. to 84 ft. Gage 250 " Diam. from ft. to ft. Gage | (12) WELL LOG: Diameter of well to Depth drilled 84 ft. Depth of compl | pelow casingeted well 84 ft. |
| " Diam. from ft. to ft. Gage | Formation: Describe color, texture, grain size a and show thickness and nature of each stratur with at least one entry for each change of formal position of Static Water Level and indicate prin | n and aquifer penetrated, tion. Report each change in |
| ') PERFORATIONS: Perforated? Yes \(\sigma\) No. | MATERIAL | From To SWL |
| pe of perforator used Mills Size of perforations in. by 2 in. | Exhisting well | 0 54 5 |
| 300 84 32 | Packed cobbles & gravel | 54 65 5 |
| perforations from | l _ | 65 70 5 |
| perforations from | Layered soft silted Packed cobbles & gravel | 70 80 5 |
| perforations from ft. to ft. | Layered soft silted | 80 84 5 |
| (7) SCREENS: Well screen installed? Yes No | | |
| Manufacturer's Name | | |
| Type Model No | | |
| Diam Slot size Set from ft. to ft. | | |
| Diam. Slot size Set from ft. to ft. | - Granse D. | |
| (8) WELL TESTS: Drawdown is amount water level is lowered below static level | = 30 Dugues | |
| Was a pump test made? Yes No If yes, by whom? | | |
| Yield: 325 gal./min. with 13 ft. drawdown after 1 hrs. 225 " 7 " 1 " | 30 because de l'approprie | |
| " " " | | |
| Bailer test gal./min. with ft. drawdown after hrs. | | |
| Artesian flow g.p.m. | | |
| mperature of water Depth artesian flow encountered ft. | Work started 7/22/70 19 Complete | ed 7/24/70 19 |
| CONSTRUCTION: | Date well drilling machine moved off of well | 7/24/70 19 |
| Well seal—Material used Exhisting Bentonite seal | Drilling Machine Operator's Certification: This well was constructed under my | direct concentrates |
| Well sealed from land surface to Exhisting ft. | Materials med and information reported | above are true to my |
| Diameter of well bore to bottom of seal | best knowledge and belief. | m/9m mo |
| Diameter of well bore below seal | [Signed] (Drilling Machine Marrate) | Date 7/27 , 19 70 |
| Number of sacks of cement used in well seal Exhisting sacks Number of sacks of bentonite used in well seal Exhisting sacks | Drilling Maghine Operator's License No. | 920 |
| Wational | | 000 |
| Druit hame of benome | Water Well Contractor's Certification: | |
| Number of pounds of bentonite per 100 gallons of water Exhisting Seal lbs./100 gals. | This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. | |
| Was a drive shoe used? 🛮 Yes 🗌 No Plugs Size: location ft. | | rilling |
| Did any strata contain unusable water? Yes No | (Person, firm or corporation) | (Type or print) |
| Type of water? depth of strata | Address Turner, Ore. | |
| Method of sealing strata off | [Signed] | 111 |
| Was well gravel packed? ☐ Yes ■ No Size of gravel: | (Water Well Contr | actor |
| Gravel placed from ft. to ft. | Contractor's License N. 410 Date 7.4 | 27/70 19 |