State Well No. 4/1 w - 34 P

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are if by

filed with the

filed with the

water well report

STATE ENGINEER, SALEM, OREGON 97310

Within 30 days from the dates are the property of the property within 30 days from the date TE ENGINEE, B not write above this line) of well completed. SALEM OREGON

State Permit No. ......

5447				
(1) OWNER:	(11) LOCATION OF WELL:			
Name LEC TERRY	County MARION Driller's well number			
Name LEC TERRY Address P.O. BOX 85 WOODBURN DRE	34 34 Section 34 T. 45 R. 1W W.M.			
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision	n corner		
New Well 🔼 Deepening 🗌 Reconditioning 🗋 Abandon 🗌  If abandonment, describe material and procedure in Item 12.				
				1.
	(12) WELL LOG: Diameter of well below casing			
Cable  Jetted  Domestic  Industrial  Municipal Dug  Bored  Irrigation  Test Well  Other	Depth drilled 153 ft. Depth of comple	eted well	150	2 ft.
	Formation: Describe color, texture, grain size			
CASING INSTALLED: Threaded Welded	and show thickness and nature of each stratus with at least one entry for each change of form			
8" Diam. from ft. to 153 ft. Gage	in position of Static Water Level as drilling pro			
" Diam, fromft_ toft_ Gage	MATERIAL	From	То	swL
" Diam, from ft, to ft, Gage	70 PSO14	U	ગ	
PERFORATIONS: Perforated? Yes   No.	CLAY YELLOW COLOR	2	49	
Type of perforator used MILLS	CLAY BLUE SILTY	49	68	
Size of perforations 1/1 in. by 25 in.	SAND SILTY BLACK	68	62	<del></del>
64 perforations from 1/3' tt. to 1/6' tt.	SAND FINE BLACK W.B.	82	82	
perforations from	CONOLOMERATE W.B.	103	1/7	
perforations from ft. to ft.	CLAY BLUE STICKY	1/2	128	
perforations from ft. to ft.	CLAYSTONE BLUE FIRM	128	152	
perforations fromft. toft.				
(7) SCREENS: Well screen installed?   Yes You				
Manufacturer's Name			٠.	
TypeModel No.				
Diam. Slot size Set from ft. to ft.				•
Diam. Slot size Set from ft. to ft.				
(8) WATER LEVEL: Completed well.				
Static level 22' ft. below land surface Date 5.2368				
A sian pressure lbs. per square inch Date				
	- 1			-
(9) WELL TESTS: Drawdown is amount water level is lowered below static level				
Was a pump test made?  Yes No If yes by whom?	Works started & A. O. O. C.			
d: gal./min. with drawdown after hrs.	Work started 5.30- 168 Complete			1968
" " " "	Date well drilling machine moved off of well	<u>5</u>	<u>23-</u>	1968
" " " " "	Drilling Machine Operator's Certification:			
Bailer test 60 gal./min. with 10 ft. drawdown after / hrs.	This well was constructed under my directed used and information reported above	ect supe e are tr	ervision.	Mate-
Artesian flow g.p.m. Die	knowledge and belief.			-
Temperature of water 57 Was a chemeal analysis made? [] Yes 🔊 No	[Signed] (Drilling Machine Operator)	Date 🔝	23.	, 1968
(10) CONSTRUCTION:	(Drining Machine Operator)	10	,	
Well seal—Material used Benronix	Drilling Machine Operator's License No	151	-	
Depth of seal 40 ft.	Water Well Contractor's Certification:			
Diameter of well bore to bottom of seain.	This well was drilled under my jurisdic	etion and	l this re	nort is
Were any loose strata cemented off? Tyet No Depth	true to the best of my knowledge and belie	f.		AD
Was a drive shoe used? Xes No	NAME J. R. SNEED & SONS. (Person, firm or corporation)		or print)	***********
Did any strata contain unusable water? Nes 🗆 No	Address 39/0 SILVERTON R			u ole
Type of water? SANOY depth d strata 82 70 /03	Address		· • · · · · · · · · · · · · · · · · · ·	
Method of sealing strata off	[Signed] K-Y. Succed			
Was well gravel packed?   Yes Wo Size of gravel:	(Water Well Contract	or)		
Gravel placed fromft.	Contractor's License No Date	5-2	3~	19.68
(USE ADDITIONAL SH	EETS IF NECESSARY)			