NOTICE TO WATER WELL CONTRACTOR [redacted]
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

JMW TO BM

MAR 10041

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED DEC 10 1976 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 8S/2W-3

State Permit No.

(1) OWNER:
Name R. Burton Hall
Address 857 Oxen ct S.E.
Salem Oregon 97301

(2) TYPE OF WORK (check):
New Well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☑ Driven ☐
Cable ☐ Jetted ☐
☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☑
6" Diam. from 0+1 ft. to 42 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☐ Yes ☑ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☑ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☑ No If yes, by whom?
ld: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Air test 10 gal./min. with 140 ft. drawdown after 1 hrs.
esian flow g.p.m.
perature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Cement Grout
Well sealed from land surface to 42 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 9 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☑ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☑ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☑ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
¼ ¼ Section 3 T. 8S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 31 ft.
Static level 38 ft. below land surface. Date 12-3-76
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 182 ft. Depth of completed well 182 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Soil	0	1	
Weathered out Rock	1	21	
Basalt Broken	21	48	
Basalt	48	79	
Basalt Partly Broken	79	110	
Basalt	110	120	
Clay Stone Gray	120	136	
Sandstone Gray	136	182	

Work started 12-1 1976 Completed 12-3 1976
Date well drilling machine moved off of well 12-3 1976

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Lonet H. Barnett (Drilling Machine Operator) Date 12-6, 1976
Drilling Machine Operator's License No. 789

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Robinson Fola Drilling (Person, firm or corporation) (Type or print)
Address 4510 Dallas Hwy. Salem Ore
[Signed] George H. Robinson (Water Well Contractor)
Contractor's License No. 13 Date 12-6, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119