NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report
are to be filed with the

WATER WELL REPORT

WATER WELL REPO
WATER RESOURCES DEPARTMENT C F V F TATE OF OREGON
SALEM, OREGON 97310
Within 30 days from the date
of well completion.

WATER WELL REPO
(Please type or print)

JUL 121977(Do not write above this line

State Permit No.

(1) OWNER: WATER RESOURCES DEPT.	(10) LOCATION OF WELL:		
Name Shangri-La Corporation SALEM, OREGON	County Marion Driller's well number 2053		
Address 2887 74 Avenue S.E.	14 14 Section 3 T. 8S R. 2W W.M.		
Salem, Oregon 97301	Bearing and distance from section or subdivision corner		
(2) TYPE OF WORK (check):			
New Well 🗷 Deepening 🗌 Reconditioning 🗍 Abandon 🗍			
If abandonment, describe material and procedure in Item 12.	(11) WATER LEVEL: Completed w	ell	
(3) TYPE OF WELL: (4) PROPOSED USE (check):	Depth at which water was first found 38 ft.		
Rotary Driven Domestic - Industrial D Municipal D	Static level 63 ft. below land surface. Date 6/11/77		
Cable	Artesian pressure lbs. per square inch. Date		
CASING INSTALLED: Threaded Weldedy	(12) WELL LOG: Diameter of well below casing Depth drilled 220 ft. Depth of completed well 220 ft. Formation: Describe color, texture, grain size and structure of materials;		
8 "Diam from LOP ft. to 52 ft. Gage 250 ft. Gage 250 ft. to 82 ft. Gage 250			
" Diam. fromft. toft. Gage			
PERFORATIONS: Perforated? Yes No.	and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.		
Type of perforator used	MATERIAL	From To	swL
Size of perforations in. by in.	Loose topsoil	0 2	
perforations from ft. to ft.	Yellow Clay	2 7	
ft. to ft.	Yellow Clay and Boulders	7 38	
perforations from ft. to ft.	loose shale	38 41	
(7) SCREENS: Well screen installed? Yes X No	Large Bounder or rock ledge	41 45	_
(1) SCREENS: Well screen installed? Yes X No Manufacturer's Name	Yellow Clay	45 47	
Type Model No,	Large boulder or rock ledge	47 61	
Diam, Slot size Set from ft. to ft.	Brown Shale	61 68	
Diam. Slot size Set from ft. to ft.	rock, Basalt Hard Blue XXXXX Shale	68 102 102 115	
	Basalt with intermittent	102 111	
(8) WELL TESTS: Drawdown is amount water level is lowered below static level	small shale strips	115 189	
Was a pump test made? X Yes No If yes, by whom? Bill Setter	_	189 195	
Yield: 50 gal./min. with 21 ft. drawdown after 5 hrs.	Fractured Rock	195 208	1
" " "	Basalt	208 220)
" Airtest 65 GPM" for a period of 2 hours "			
Bailer test gal./min. with ft. drawdown after hrs.			
Artesian flow g.p.m.			
perature of water Depth artesian flow encountered ft.	Work started 6/7/77 19 Complete	ed 6/11/77	
			19
(9) CONSTRUCTION:	Date well drilling machine moved off of well	6/11/77	19
Well seal—Material used Portland Cement	Drilling Machine Operator's Certification:		
Well sealed from land surface to	This well was constructed under my direct supervision. Materials used and information reported above are true to my		
Diameter of well bore to bottom of seal 12 in. Diameter of well bore below seal 8"to 82 6" fo 220"	best knowledge and belief.		
	[Signed] All So Polls Date 6/11/77, 19 Date 1/17, 19		
Number of sacks of cement used in well seal sacks How was cement grout placed? PIESSURE grouted with pump	Drilling Machine Operator's License No		
The Content growt placed, plac			
	Water Well Contractor's Certification:		
Was a drive shoe used? ▼ Yes □ No Plugs Size: location ft.	This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Did any strata contain unusable water? Yes No	Name Willamette Drillling Co. (Person, firm or corporation) (Type or print)		
Type of water? depth of strata	Address 1450 Barnick Rd. NE Salem, Oregon 97303		
Method of sealing strata off	O.M. DRAN		
***	[Signed] & Lafton & Della (Water Well Contractor)		
Was well gravel packed? ☐ Yes 🔏 No Size of gravel:	i		.
Gravel placed from ft. to ft.	Contractor's License No561 Date6	71.77	, 19