

10060

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED AUG 3 1966 STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON (Please type or print)

MAR... State Well No. 8/26-103 State Permit No.

(1) OWNER:

Name SHANGRA LA. SCHOOL  
 Address 7373 GALE ST. SALEM ORE

(2) LOCATION OF WELL:

County MARION Driller's well number  
 1/4 Section 10 T. 8S R. 2W W.M.  
 Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well  Deepening  Reconditioning  Abandon   
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic  Industrial  Municipal  Irrigation  Test Well  Other   
 Rotary  Cable  Dug  Driven  Jetted  Bored

(6) CASING INSTALLED:

6" Diam. from 0 ft. to 56' ft. Gage 17.62"  
 Threaded  Welded

(7) PERFORATIONS:

Perforated?  Yes  No  
 Type of perforator used TORCH  
 Size of perforations 3/8 in. by 8" in.  
 10 perforations from 45' ft. to 53' ft.

(8) SCREENS:

Well screen installed?  Yes  No  
 Manufacturer's Name  
 Type Model No.  
 Slot size Set from ft. to ft.  
 Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal BENTONITE  
 Depth of seal 44' ft. Was a packer used? yes  
 Diameter of well bore to bottom of seal 9 1/2" in.  
 Were any loose strata cemented off?  Yes  No Depth  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: 3/4 ROUND  
 Gravel placed from 44'6" ft. to 54' ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? depth of strata  
 Method of sealing strata off

(10) WATER LEVELS:

Static level 18 ft. below land surface Date 7-29-66  
 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? SNEED & SONS  
 Yield: 12 gal./min. with 95 ft. drawdown after 2 hrs.  
 " " " " " "  
 " " " " " "  
 Bailer test gal./min. with ft. drawdown after hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water 53° Was a chemical analysis made?  Yes  No

(12) WELL LOG:

Diameter of well below casing 6"  
 Depth drilled 114' ft. Depth of completed well 114' ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TURSOIL	0	2
CLAY YELLOW COLOR	8	21
BASALT BROKEN	21	55
BASALT DENSE	55	102
BASALT BROKEN	102	104
BASALT DENSE	104	114

Work started 7-28 1966 Completed 7-29-1966  
 Date well drilling machine moved off of well 7-29-1966

(13) PUMP:

Manufacturer's Name  
 Type: SUBMERSIBLE H.P. 3/4

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J.P. SNEED & SONS (Person, firm or corporation) (Type or print)  
 Address 3910 SILVERTON RD. SALEM, ORE  
 Drilling Machine Operator's License No. 187  
 [Signed] J.P. Sneed (Water Well Contractor)  
 Contractor's License No. 6 Date 7-29-1966