

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED

OCT 13 1975

STATE OF OREGON (Please type or print)

(Do not write above this line)

MA. RI. 10/85

State Well No. 85/2W-13

State Permit No. G-7322

(1) OWNER:

Name: Franks Lumber Company test hole #1
Address: P. O. Box 1467, Mill City, Oregon 97360

(2) TYPE OF WORK (check): TEST HOLE

New Well [ ] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary [x] Cable [ ] Dug [ ] Driven [ ] Jetted [ ] Bored [ ]

(4) PROPOSED USE (check):

Domestic [ ] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [x] Other [ ]

CASING INSTALLED:

8" Diam. from 0 ft. to 60 ft. Gage .250
Threaded [ ] Welded [x]

PERFORATIONS:

TEST HOLE
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? [ ] Yes [x] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [ ] Yes [x] No
Yield: gal./min. with ft. drawdown after hrs.
AIR test 300 gal./min. with 300 ft. drawdown after 2 hrs.

(9) CONSTRUCTION:

Well seal—Material used cement
Well sealed from land surface to 5.0 ft.
Diameter of well bore to bottom of seal 12 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 10 sacks
Number of sacks of bentonite used in well seal
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water
Was a drive shoe used? [ ] Yes [x] No
Did any strata contain unusable water? [ ] Yes [x] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [ ] Yes [x] No
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 134873B
SE 1/4 NW 1/4 Section 13 T. 8S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 101 ft.
Static level XXXXXXXX ft. below land surface. Date
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

TEST HOLE
Diameter of well below casing 8"
Depth drilled 605 ft. Depth of completed well 605 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, From, To, SWL. Rows include brown clay, blue pumice, green clay, brown sandstone, blue gummy clay, blue clay stone, blue sand stone, light blue sand stone, gray sand stone, blue sand stone, sandstone (blue green), sandstone (light blue), sandstone (green), clay stone (blue), clay stone and quartz (blue).

Work started 6-7 1973 Completed 6-26 1973
Date well drilling machine moved off of well 6-26 1973

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] W. A. Parkhalls Date 8/29, 1973
Drilling Machine Operator's License No. 419

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Schoen Electric & Pump
Address 626 W. Queen - Albany, Or. 97321
[Signed] Sam E. Schen Date 8/29, 1973
Contractor's License No. 513