NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED SEP 29 1964 STATE ENGINEER

MAR 21 102164

WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 8/2W-14

State Permit No.

(1) OWNER:

Name J. L. Amort

Address 7600 Aumsville Highway, S. E.
Salem, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number 64.22

¼ ¼ Section 14 T. 8 S R. 2 W W.M.

Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒

6" Diam. from 0 ft. to 45 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS: Perforated? ☐ Yes ☒ No

Type of perforator used

Size of perforations in. by in.

perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? ☐ Yes ☐ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal ¼- crush & drill Mud

Depth of seal 28 ft. Was a packer used? no

Diameter of well bore to bottom of seal 10 in.

Were any loose strata cemented off? ☐ Yes ☒ No Depth

Was a drive shoe used? ☐ Yes ☒ No

Was well gravel packed? ☒ Yes ☐ No Size of gravel: 3/4 rnd

Gravel placed from 28 ft. to 45 ft.

Did any strata contain unusuable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

(10) WATER LEVELS:

Static level 19 ft. below land surface Date 9-22-64

Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☐ Yes ☒ No If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Bailer test 20 gal./min. with 30 ft. drawdown after 1 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☒ No

(12) WELL LOG: Diameter of well below casing 6"

Depth drilled 78 ft. Depth of completed well 78 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifiers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Clay and gravel fill	0	3
Red top soil and clay	3	15
Brown decomposed basalt - not hard - few boulders	15	45
Hard ledge of black basalt or boulder	45	50
Partley decomposed basalt - hard and soft layers	50	75
Grey claystone or tuff	75	78

Work started 9-18 19 64 Completed 9-22 19 64

Date well drilling machine moved off of well 9-24 19 64

(13) PUMP:

Manufacturer's Name

Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME West Well Drilling
(Person, firm or corporation) (Type or print)

Address 4098 Market Street, N.E., Salem

Drilling Machine Operator's License No. 188

[Signed] Marion E. West
(Water Well Contractor)

Contractor's License No. 30 Date 9-28, 19 64

(USE ADDITIONAL SHEETS IF NECESSARY)