RECEIVED MAR 1 1063

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

RECEIVED NOV 25 1977 WATER RESOURCES DEPT. SALEM, OREGON

RECEIVED DEC 5 1977 WATER RESOURCES DEPT. SALEM, OREGON

State Well No. 4S/2W-4ac

State Permit No.

(1) OWNER:
Name John Rasmussen
Address 109 Viewmont Dr. Dundee, Ore. 97115

(2) TYPE OF WORK (check):
New Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐ seal only
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

CASING INSTALLED: Threaded ☐ Welded ☒
10" Diam. from 0 ft. to +4 ft. Gage .250
" Diam. from ft. to ft. Gage
added to existing casing
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? ☐ Yes ☐ No.
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☐ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☐ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used cement, bentonite readimix
Well sealed from land surface to 30 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal - in.
Number of sacks of cement used in well seal 214 sacks
How was cement grout placed? 147 sk cement was grouted in from 30 to 5' level - then rest was filled w/ 13½ cu yd of 5 sk readimix to + 1½'
Was a drive shoe used? ☐ Yes ☐ No Plug Size: location ft.
Did any strata contain unusable water? ☐ Yes ☐ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☐ No Size of gravel: pea
Gravel placed from 30 ft. to ? ft.

(10) LOCATION OF WELL:
County Marion Driller's well number 7722
SW ¼ NE ¼ Section 4 T. 4S R. 2W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found ft.
Static level 6 outside casing 50 inside ft. below land surface. Date 10-5-77
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 10-5-77
Depth drilled ft. Depth of completed well 303 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Work was done to an existing well for which we have no log drilled by J.T. Miller			
4' of 10" casing was added to existing casing. We dug out w/ backhoe to 5' and found concrete 0-3' then approx 3' annular space open around the casing. After putting in 1½ yd pea gravel from ? to 30' we pumped 147 sk of groute in from 30' to 5' level. Then 13½ cu yd of 5 sk readimix was used to fill to a plus 1½' level. Customer to fill around to leave 1½ to 2' stick up.			

Work started 10-6- 19 77 Completed 10-21 19 77
Date well drilling machine moved off of well NOT used

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Mike Schneider (Drilling Machine Operator) Date 11-21, 19 77
Drilling Machine Operator's License No. 212

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Schneider Equipment, Inc. (Person, firm or corporation) (Type or print)
Address Star Rt., Box 97, St. Paul, Ore. 97137
[Signed] Mike Schneider (Water Well Contractor)
Contractor's License No. 387 Date 11-21, 19 77

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119