

WATER WELL REPORT
STATE OF OREGON

State Well No. 85/2w-20
State Permit No. _____

RECEIVED
MAR 21 1982
10/4/33
WATER RESOURCES DEPT.
SALEM, OREGON

(1) OWNER:

Name Dale Jones
Address 233 Howell Prairie Rd. S.E.
City Salem State Oregon

LOCATION OF WELL:

County Marion Driller's well number _____
1/4 Section 20 T. 8S R. 2W W.M.
Tax Lot # _____ Lot _____ Blk _____ Subdivision _____
Address at well location: Ahrens Rd.
Turner, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven
Rotary Mud Dug
 Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal Reinjection

(5) CASING INSTALLED:

Steel Plastic
Threaded Welded
6" Diam. from +1 ft. to 29 ft. Gauge .250
" Diam. from _____ ft. to _____ ft. Gauge _____

LINER INSTALLED:

4" Diam. from 0 ft. to 170 ft. Gauge 160 PSI PVC

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used Electric Saw
Size of perforations 1/8 in. by 8 in.
150 perforations from 110 ft. to 160 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Type _____
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot Size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Air Test May Fluctuate
Air test 38 gal./min. with drill stem at 170 ft. 1 hrs.
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m.
Temperature of water _____ Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Special standards: Yes No
Well seal—Material used Cement
Well sealed from land surface to _____ ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal _____ sacks
How was cement grout placed? Air Grout Pump

Was pump installed? Yes Type Sub HP 1 1/2 Depth 157 ft.
Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of Water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.

(11) WATER LEVEL: Completed well.

Depth at which water was first found 120 ft.
Static level 85 ft. below land surface. Date 1-29-81
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing 6
Depth drilled 170 ft. Depth of completed well 170 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Decomposed Rock	0	3	
Brown Clay	3	11	
Tan Clay	11	18	
Dark Gray Sticky Clay	18	21	
Gray Shale	21	65	
Light Gray Shale	65	115	
Multi-Colored Sandstone	115	136	
Light Gray Sandstone	136	157	
Multi-Colored Sandstone	157	170	85'

Work started 1-26 19 82 Completed 1-28 19 82
Date well drilling machine moved off of well 1-28 19 82

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] J.D. Mondora Date 1-30, 19 82
(Drilling Machine Operator)
Drilling Machine Operator's License No. 1195

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name MILLER, WEST WELL DRILLING (Type or print)
Address 5875 Gaffin Rd. S.E. Salem, Oregon
[Signed] Gary Mondora (Water Well Contractor)
Contractor's License No. 722 Date 1-30, 19 82

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12658-690