

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED

AUG 11 1966 WATER WELL REPORT

MARI.#.02

RECEIVED

AUG 16 1966

State Well No. 4/26-6 E

(Please type or print)

STATE G-3599 FE State Permit No.

(1) OWNER:

Name Fred Hiller
Address St. Paul Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number
NW 1/4 NW 1/4 Section 6 T. 4S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal Rotary Driven
Irrigation Test Well Other Cable Jetted
Dug Bored

(5) TYPE OF WELL:

(6) CASING INSTALLED:

Threaded Welded
.16" Diam. from 0 ft. to 23 ft. Gage .250
.12" Diam. from 0 ft. to 118 ft. Gage .250
" Diam. from " ft. to " ft. Gage "

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used torch
Size of perforations 1/2 in. by 12 in.
492 perforations from 23 ft. to 64 ft.
60 perforations from 81 ft. to 86 ft.
84 perforations from 110 ft. to 117 ft.
perforations from " ft. to " ft.
perforations from " ft. to " ft.

(8) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Slot size Set from " ft. to " ft.
Diam. Slot size Set from " ft. to " ft.

(9) CONSTRUCTION:

Well seal—Material used in seal bentonite, clay, silt
Depth of seal 23 ft. Was a packer used? no
Diameter of well bore to bottom of seal 20 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3/4 minus
Gravel placed from 23 ft. to 117 ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 11 ft. below land surface Date 7-15-66
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? driller
Yield: 255 gal./min. with 65 ft. drawdown after 4 hrs.
" " " "
" " " "
" " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 6 in.
test hole
Depth drilled 201 ft. Depth of completed well 118 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
soil	0	1
brown clay	1	9
layers of brown sand water & clay	9	13
dirty brown sand & water	13	33
sand & water	33	43
very dirty grey sand water	43	57
brown sandy clay	57	58
brown medium sand water	58	64
grey sandy clay	64	81
grey-brown dirty sand & water	81	85
brown decomposed compacted sand	85	86
grey sandy clay	86	103
decomposed sand	103	117
sandy clay alternate layers of grey and brown	117	196
decomposed sand	196	201
grey-brown sand clay	201	201'6"

Work started 6-9 1966 Completed 7-15 1966
Date well drilling machine moved off of well 7-28 1966

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George Zent & Sons 4305 N.E. 44th St.
(Person, firm or corporation) (Type or print)

Address Vancouver, Washington 98661

Drilling Machine Operator's License No. 213

[Signed] George Zent
(Water Well Contractor)

Contractor's License No. 228 Date 8-10, 1966.