

RECEIVED

MAR 11 1963

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

JAN 28 1963

WATER WELL REPORT

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

STATE ENGINEER SALEM, OREGON

STATE OF OREGON (Use type or print)

State Well No. 4/2W-7H

State Permit No.

(1) OWNER:

Name Milo Schneider
Address Star Rt., Box 97
St. Paul, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number
1/4 1/4 Section 7 & 8 T. 4S R. 2W W.M.
Bearing and distance from section or subdivision corner
S. 19 Ch N. 34 - 47' W. of N.E. Cor
Cl #97 Township 4S R 2W Sec 7 & 8

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon []
If [] monument, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal []
Irrigation [X] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [X] Driven []
Cable [] Jetted [X]
Dug [] Bored []

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 96 ft. Gage 188
8" Diam. from 96 ft. to 156 ft. Gage 250

(7) PERFORATIONS:

Type of perforator used TORTH
Size of perforations 1/4 in. by 10 in.
320 ea perforations from 96 ft. to 156 ft.

(8) SCREENS:

Well screen installed [] Yes [X] No
Manufacturer's Name
Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal-Material used in seal Concrete
Depth of seal 13' ft. Was a packer used? No
Diameter of well bore to bottom of seal 20" in.
Were any loose strata cemented off? [] Yes [X] No
Was a drive shoe used? [] Yes [X] No
Was well gravel packed? [X] Yes [] No Size of gravel: 3/4 20yds
Gravel placed from 13 ft. to 156 ft.
Did any strata contain unusable water? [] Yes [X] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 14 ft. below land surface Date 4-15-62
Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [] No If yes, by whom? Milo Schneider
Yield: 800 gal./min. with 92 ft. drawdown after 8 hrs.
700 " 78 " 8 1/2 "
500 " 56 " 9 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water 55 Was a chemical analysis made? [] Yes [X] No

(12) WELL LOG:

Diameter of well below casing 153
Depth drilled 156 ft. Depth of completed well ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include 0 to 2 top soil, brown clay, brown clay w/ sand layers, blue clay few sand layers, hard blue clay, sand & wood, sand & layers brown clay, brownish yellow clay.

Pump was set 146' overall
Air line 130' with direct reading gauge

Work started 3-10-62 Completed 12-29-62
Date well drilling machine moved off of well 19

(13) PUMP:

Manufacturer's Name Layne & Bowler
Type: turbine H.P. 25

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Milo Schneider
Address Star Rt., Box 97, St. Paul

Drilling Machine Operator's License No. 212

[Signed] Milo Schneider (Water Well Contractor)

Contractor's License No. 387 Date 12-29, 19 62