

RECEIVED
MAY 13 1968
STATE ENGINEER OF OREGON
SALEM, OREGON

G-2648

MARI 1117
 4/2W-8F

NOTICE TO WATER WELL CONTRACTOR:
 The original and first copy
 of this report are to be
 filed with the
 STATE ENGINEER, SALEM 10, OREGON
 within 30 days from the date
 of well completion.

WATER WELL REPORT
STATE ENGINEER OF OREGON
 (Please type or print)

State Well No. 4/2W-8F
 State Permit No. _____

(1) OWNER:

Name Tribbett & Son
 Address Newberg, Oregon

(2) LOCATION OF WELL:

County Marion Driller's well number _____
SE 1/4 NW 1/4 Section 8 T. 4S R. 2W W.M.
 Bearing and distance from section or subdivision corner
1430' South & 1580 East from NW Corner of
Section 8

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
12" Diam. from +1 ft. to 205'2" ft. Gage .250
" Diam. from " ft. to 206'2" ft. Gage total
18" Diam. from +1 ft. to 191' ft. Gage .250

(7) PERFORATIONS:

Perforated? Yes No
 Type of perforator used torch
 Size of perforations 5/16 x 8 in. by in.
420 perforations from 18' ft. to 53'3" ft.
240 perforations from 72'3" ft. to 92'5" ft.
492 perforations from 145'11" ft. to 186'9" ft.
With Miller knife from 2' x 3' ft. to _____ ft.
240 perforations from 115' ft. to 145' ft.

(8) SCREENS:

Well screen installed Yes No
 Manufacturer's Name _____
 Model No. _____
 Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement
 Depth of seal 20' ft. Was a packer used? _____
 Diameter of well bore to bottom of seal 30" in.
 Were any loose strata cemented off? Yes No Depth 202'
 Was a drive shoe used? Yes No _____
 Was well gravel packed? Yes No Size of gravel: 3/4" - 1/2"
 Gravel placed from 20 ft. to 186 ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 20 ft. below land surface Date _____
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: 1100 gal./min. with 89 ft. drawdown after 6 hrs.
 " 900 " 71 " 6 1/2 "
 " 835 " 60 " 7 "
 " 700 " 45 " 8 "
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water 56 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 0
 Depth drilled 208 ft. Depth of completed well 202 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
top soil	0	3
brown clay	3	57
grey sand fine	57	64
black sand	64	79
blue clay	79	84
soft clay & layers of sand	84	96
blue clay	96	100
sand	100	105
hard brown clay	105	110
clay & layers of sand	110	150
hard brown clay	150	164
brown sand	164	168
hard brown clay	168	173
b. clay & sand layers	173	185
brown clay	185	191
blue clay	191	208
This was an abandoned well. We pulled 335' of 12" casing and reamed to 20" and reset		

Work started 3-8 19 _____ Completed 4-23 19 63
 Date well drilling machine moved off of well _____ 19 _____

(13) PUMP:

Manufacturer's Name none
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Milo Schneider Equipment Co.
 (Person, firm or corporation) (Type or print)

Address Star Rt., Box 97, St. Paul, Oregon

Drilling Machine Operator's License No. 212

[Signed] Milo Schneider
 (Water Well Contractor)

Contractor's License No. 387 Date 4-29, 19 63