

**RECEIVED**  
 SEP - 4 1962  
 STATE ENGINEER  
 SALEM, OREGON

MARI...119  
 (61)

NOTICE TO WATER WELL CONTRACTOR  
 The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

State Well No. 4/2 W - 82  
 State Permit No. \_\_\_\_\_

**(1) OWNER:**  
 Name Nelson Tribbett & Son  
 Address Star Rt., Box 96  
St. Paul, Oregon

**(2) LOCATION OF WELL:**  
 County Marion Driller's well number \_\_\_\_\_  
NW 1/4 NE 1/4 Section 8 T. 4S R. 2W W.M.  
 Bearing and distance from section or subdivision corner  
2000 feet South - 1500 feet West from  
NE Cor. Section 8, T4S, R2W

**(3) TYPE OF WORK (check):**  
 Well  Deepening  Reconditioning  Abandon   
 If abandonment, describe material and procedure in Item 12.

**(4) PROPOSED USE (check):** Domestic  Industrial  Municipal   
 Irrigation  Test Well  Other   
**(5) TYPE OF WELL:** Rotary  Driven   
 Cable  Jetted   
 Dug  Bored

**(6) CASING INSTALLED:** Threaded  Welded   
 \_\_\_\_\_" Diam. from none ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 \_\_\_\_\_" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
 \_\_\_\_\_" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**(7) PERFORATIONS:** Perforated?  Yes  No  
 Type of perforator used Mills Knife  
 Size of perforations 3/8 x 2in. by \_\_\_\_\_ in.  
 \_\_\_\_\_ 120 perforations from 150 ft. to 160 ft.  
 \_\_\_\_\_ 400 perforations from 120 ft. to 145 ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 \_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) SCREENS:** Well screen installed  Yes  No  
 Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(9) CONSTRUCTION:**  
 Well seal—Material used in seal concrete  
 Depth of seal 10 ft. Was a packer used? \_\_\_\_\_  
 Diameter of well bore to bottom of seal 5 feet in.  
 Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
 Was a drive shoe used?  Yes  No  
 Was well gravel packed?  Yes  No Size of gravel: 3/4 minus  
 Gravel placed from 10' ft. to 160' ft.  
 Did any strata contain unusable water?  Yes  No  
 Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
 Method of sealing strata off \_\_\_\_\_

**(10) WATER LEVELS:**  
 Static level 24 ft. below land surface Date 7-30-62  
 Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(11) WELL TESTS:** Drawdown is amount water level is lowered below static level  
 Was a pump test made?  Yes  No If yes, by whom? Driller  
 Yield: 400 gal./min. with 66 ft. drawdown after 8 hrs.  
 " " " "  
 " " " "  
 Baller test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
 Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
 Temperature of water 52 Was a chemical analysis made?  Yes  No

**(12) WELL LOG:** Diameter of well below casing \_\_\_\_\_  
 Depth drilled \_\_\_\_\_ ft. Depth of completed well 171 ft.  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Pulled 140' of 12" casing		
Pulled 84' of 8" casing		
Pulled 84' of 2" pipe was in the 8"		
Note: the 12" was around the 8" that is left		
the 84' of 8" was on the outside of the 12"		
the 2" was inside of the above 8" and full of gravel		
Installed 2 feed pipes 5" x 118" and 5" x 222" to top of concrete		

Work started \_\_\_\_\_ 19 \_\_\_\_\_ Completed 8-1-62 19 \_\_\_\_\_  
 Date well drilling machine moved off of well 8-1-62 19 \_\_\_\_\_

**(13) PUMP:** Manufacturer's Name Layne & Bowler  
 Type: Turbine set 157' overall H.P. 30  
airline 140'  
 Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Milo Schneider (Person, firm or corporation) (Type or print)  
 Address Star Rt., Box 97 St. Paul, Oregon  
 Drilling Machine Operator's License No. 212  
 [Signed] Milo Schneider (Water Well Contractor)  
 Contractor's License No. 387 Date 8-30, 1962