

WATER WELL REPORT
STATE OF OREGON

RECEIVED

MAY 25 1982

WATER RESOURCES DEPT.

SALEM, OREGON

State Well No. 85/2W-33

State Permit No. 6-9364
WELL #3

MARION
11266
MAR

(1) OWNER:

Name DON ETZEL
Address 8806 Marion Rise
City Turner State Ore

(10) LOCATION OF WELL:

County Marion Driller's well number
1/4 1/4 Section 33 T. 8S R. 2W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location:

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Air Driven Domestic Industrial Municipal
Rotary Mud Dug Irrigation Test Well Other
 Bored Thermal Withdrawal Reinjection

(4) PROPOSED USE (check):

(11) WATER LEVEL: Completed well.

Depth at which water was first found 32 ft.
Static level 4 ft. below land surface. Date 6/30/81
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 12 in.
Depth drilled 120 ft. Depth of completed well 120 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
clay & gravel	0	20	
sand clay & gravel	20	32	
sand med to large gravel	32	45	
cemented gravel	45	53	
small to large gravel	53	84	
brown sand & gravel	84	87	
clay & gravel	87	95	
small to large gravel	95	108	
brown clay	108	120	

~~Corrected Copy 5/2/82~~

CASING INSTALLED:

Steel Plastic
Threaded Welded
12" Diam. from 71 ft. to 118 ft. Gauge 250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:

" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:

Perforated? Yes No
Type of perforator used mills
Size of perforations 3/8 in. by 3 in.
672 perforations from 58 ft. to 108 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Stettlers Supply
440 gal./min. with 76 ft. drawdown after 4 hrs.
Air test gal./min. with drill stem at ft. hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Nature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Special standards: Yes No
Well seal—Material used cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 16 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal 14 sacks
How was cement grout placed? pumped
Was pump installed? Type HP Depth ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

Work started 6-24 19 81 Completed 6-30 19 81
Date well drilling machine moved off of well 6-30 19 81

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
(Signed) Norman D. Terrell Date 7/3, 19 81
(Drilling Machine Operator)
Drilling Machine Operator's License No. 455

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name EOLA WELL DRILLING
(Person, firm or corporation) 4510 Oregon Rd. N.W. (Type or print)
Address SALEM, OR. 97304
(Signed) Hermit & Berard
(Water Well Contractor)
Contractor's License No. 619 Date 6-7, 19 81

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12858-690