

MARI. 1138

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 4/2W-9R1

State Permit No.

AUG 19 1964

(1) OWNER:

Name Don Oliver Address

(2) LOCATION OF WELL:

County Marion Driller's well number 1/4 1/4 Section 9 T. 4S R. 2W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [x] Deepening [ ] Reconditioning [ ] Abandon [ ] In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [x] Industrial [ ] Municipal [ ] Irrigation [x] Test Well [ ] Other [ ]

(5) TYPE OF WELL:

Rotary [ ] Driven [ ] Cable [ ] Jetted [ ] Dug [ ] Bored [ ]

(6) CASING INSTALLED:

18" Diam. from 0 ft. to 20 ft. Gage 250 12" Diam. from 0 ft. to 147 ft. Gage 250 4" Diam. from 0 ft. to 136-25" Gage

(7) PERFORATIONS:

Perforated? [x] Yes [ ] No Type of perforator used Torch Size of perforations 5/16 in. by 8 in. 12" 6.96 perforations from 0 ft. to 145 ft. 4" 3.6 perforations from 12.87 ft. to 75 ft. 3.0 perforations from 70 ft. to 18.6 ft. 9.0 perforations from 160 ft. to 131 ft.

(8) SCREENS:

Well screen installed? [ ] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Concrete Depth of seal 20 ft. Was a packer used? no Diameter of well bore to bottom of seal 30 in. Were any loose strata cemented off? [x] Yes [ ] No Depth Was a drive shoe used? [x] Yes [ ] No Was well gravel packed? [x] Yes [ ] No Size of gravel: 3/8-3/4 Gravel placed from 0 ft. to 146 ft. Did any strata contain unusable water? [ ] Yes [x] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 65 ft. below land surface Date 7/10/64 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [ ] Yes [ ] No If yes, by whom? Yield: 600 gal./min. with 15 ft. drawdown after 6 hrs. 1400 " 43 " 6 1/2 " 1600 " 49 " 7 " Bailer test 1800 gal./min. with 55 ft. drawdown after 7 1/2 hrs. Artesian flow g.p.m. Date Temperature of water 60 Was a chemical analysis made? [ ] Yes [ ] No

(12) WELL LOG:

Diameter of well below casing 8 Depth drilled 147 ft. Depth of completed well 146 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns: MATERIAL, FROM, TO. Entries include Top Brown Clay, Soft Brown Clay with layers of fine sand, Brown Clay, Hard Blue Clay, Soft Brown Clay, fine sand to coarse sand, Brown Clay.

Note 4" was drilled 12" north of well for Domestic and has 3/4 h.p. Jacuzzi submersible pump in it on 1" pipe (50 h.p. has 4x8" access Port.)

Work started 6-8 1964 Completed 7-27 1964 Date well drilling machine moved off of well 7-27 1964

(13) PUMP:

Manufacturer's Name Loyne & Bowler Type: turbine 1/2-1 1/2" H.P. 50

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Mike Schneider Equip. Co. (Person, firm or corporation) (Type or print) Address 136 97

Drilling Machine Operator's License No. 212

[Signed] Mike Schneider (Water Well Contractor)

Contractor's License No. 387 Date 8-10-64