

MARI...1146

RECEIVED

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

SEP 12 1962

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 4/2W-12 J 1 State Permit No.

(1) OWNER:

Name Kirsch Bros Address Rt. 1, Aurora, Oregon Box 119.

(2) LOCATION OF WELL:

County Marion Driller's well number NE 1/4 SE 1/4 Section 12 T. 43 R. 2 W.M. Bearing and distance from section or subdivision corner 1550' N and 600' W from the S.E. corner of section 12 Formerly Killian Smith well #4

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandonment

(4) PROPOSED USE (check):

Domestic Industrial Municipal Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Cable Dug Driven Jetted Bored

(6) CASING INSTALLED:

10" Diam. from 0 ft. to 12 ft. Gage 250 on top of present casing

(7) PERFORATIONS:

Type of perforator used Mills Knife Size of perforations 3/8 in. by 2 in. 400 perforations from 82 ft. to 107 ft.

(8) SCREENS:

Well screen installed Manufacturer's Name Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Depth of seal ft. Was a packer used? Diameter of well bore to bottom of seal in. Were any loose strata cemented off? Yes No Depth Was a drive shoe used? Yes No Was well gravel packed? Yes No Size of gravel: 3/4 - 1/2 Gravel placed from 0 ft. to 110 ft. 60 yds Did any strata contain unusable water? Yes No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 27 ft. below land surface Date 8-13-62 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? Yield: 400 gal./min. with 55 ft. drawdown after 3 hrs. 350 " 28 " 4 " Baller test gal./min. with ft. drawdown after hrs. Artesian flow g.p.m. Date Temperature of water 54 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 2 Depth drilled 120-8 ft. Depth of completed well 120 ft. 8" Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Content: Well filled with sand to 112' Casing settled by itself without driving. There was an old hole along side that settled and we poured full of gravel also. There was space around the casing for gravel. Pump was set 116' 6" overall. We reinstalled it the same depth. Coarse gravel to 3" at 120' 8"

Work started 7-31 19 62 Completed 8-14 19 62 Date well drilling machine moved off of well 8-14 19 62

(13) PUMP:

Manufacturer's Name Johnston Type: Turbine H.P. 25

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Milo Schneider Equipment Co. (Person, firm or corporation) (Type or print) Address Star Rt., Box 97, St. Paul, Oregon Drilling Machine Operator's License No. 212 [Signed] Milo Schneider (Water Well Contractor) Contractor's License No. 387 Date 8-14 19 62