ORIGINAL
File Original and Duplicate with the STATE ENGINEER, SALEM, OREGON

M1 11519

WATER WELL REPORT
STATE OF OREGON

State Well No. 8/3W-7J(1)

State Permit No. .....

(1) OWNER:

Name Alex Agalzoff

Address Rt 3 Box 570 Salem Ore

(2) LOCATION OF WELL:

County ~~Marion~~ Marion Owner's number, if any— #1

NE ¼ SE ¼ Section 7 T. 8S R. 3W W.M.

Bearing and distance from section or subdivision corner 900 feet South 650 West from E¼ Cor. 821 FT FROM Sect. 7. NORTH LINE 458 FROM CENTER OF ROAD.

N W E S

(3) TYPE OF WORK (check):

New Well ☐ Deepening ☐ Reconditioning ☒ Abandon ☐

If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐

Irrigation ☒ Test Well ☐ Other ☐

(5) TYPE OF WELL:

Rotary ☐ Driven ☐

Cable ☒ Jetted ☐

Dug ☐ Bored ☐

(6) CASING INSTALLED: Threaded ☐ Welded ☒

6 5/8" Diam. from ½ + 0 ft. to 32½ ft. Gage .280

..... " Diam. from ..... ft. to ..... ft. Gage .....

..... " Diam. from ..... ft. to ..... ft. Gage .....

(7) PERFORATIONS: Perforated? ☐ Yes ☒ No

Type of perforator used

SIZE of perforations ..... in. by ..... in.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

..... perforations from ..... ft. to ..... ft.

(8) SCREENS: Well screen installed ☐ Yes ☒ No

Manufacturer's Name ..... Model No. .....

Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

Diam. ..... Slot size ..... Set from ..... ft. to ..... ft.

(9) CONSTRUCTION:

Was well gravel packed? ☐ Yes ☒ No Size of gravel: .....

Gravel placed from ..... ft. to ..... ft.

Was a surface seal provided? ☐ Yes ☐ No To what depth? 32½ ft.

Material used in seal—

Did any strata contain unusable water? ☒ Yes ☐ No

Type of water? surface Depth of strata 10 ft.

Method of sealing strata off Refer to log

(10) WATER LEVELS:

Static level 164 ft. below land surface Date 2-16-55

Artesian pressure none lbs. per square inch Date

Log Accepted by:

[Signed] [signature] (Owner) Date 5-18-, 1957

(11) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? STETTLER

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? ☐ Yes ☐ No

(12) WELL LOG: Diameter of well 6 inches.

Depth drilled ft. Depth of completed well 289 ft.

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Reamed hole to 10" cleaned out well to 289 Found shale mixed with Rock cutting at 289 ft well reported to be 305 ft deep orignally	0.	30



Work started 4-29 1957 Completed 5-2 195

(13) PUMP:

Manufacturer's Name ..... H.P. .....

Type: .....

Well Driller's Statement:

This well was drilled under my jurisdiction and this report true to the best of my knowledge and belief.

NAME H A Robinson (Person, firm, or corporation) (Type or print)

Address 2214 N. Front St Salem O

Driller's well number 8/3W-7J1

[Signed] Harry A Robinson (Well Driller)

License No. 22 Date May 3, 19