

NOTICE TO WATER WELL CONTRACTOR.

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED

WATER WELL REPORT STATE OF OREGON (Please type or print)

MARI... 1152

State Well No. 4/2w-12
State Permit No.

STATE ENGINEER

(1) OWNER: SALEM OREGON
Name: H.R. Drury
Address: Rt. 1 Box 218, Aurora, Ore

(2) LOCATION OF WELL:
County: Marion Driller's well number: #3
1/4 Section: 12 T. 4S R. 2W W.M.
Bearing and distance from section or subdivision corner: #3 452'

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
In abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal Irrigation Test Well Other
(5) TYPE OF WELL:
Rotary Driven Cable Jetted Dug Bored

(6) CASING INSTALLED:
18" Diam. from 0 ft. to 45 ft. Gage 1.250
12" Diam. from 0 ft. to 11.4 ft. Gage 1.250
16" Diam. from 11.4 ft. to 115 ft. Gage 1.375

(7) PERFORATIONS:
Type of perforator used: Torch
Size of perforations: 3/8 in. by 7 in.
600 perforations from 62 ft. to 112 ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name: _____ Model No. _____
Diam. Slot size Set from _____ ft. to _____ ft.
Diam. Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal: Bentonite
Depth of seal: 39 ft. Was a packer used? Yes No
Diameter of well bore to bottom of seal: 24 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: 3-38
Gravel placed from 0 ft. to 111 ft. *5 ft. casing*
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level: 20 ft. below land surface Date: 4-24-65
Artesian pressure: _____ lbs. per square inch Date: _____

(11) WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 1680 gal./min. with 80 ft. drawdown after 5 hrs.
" 980 " " 43 " " 5 1/2 "
" 750 " " 36 " " 4 "
Bailer test: 520 gal./min. with 81 ft. drawdown after 4 1/2 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water: 54 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing _____
Depth drilled: 115 ft. Depth of completed well: 112 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
top	0	2
Brown Clay	2	8
Sandy loam	8	25
Brown Clay	25	40
" "	40	47
Sandy loam	47	48
Light Brown Clay	48	50
extra light " "	50	52
Hard clayey " "	52	80
Dark " "	80	83
Sand	83	111
Brown Clay	111	115

NOTE: 16" Ball 12" long on bottom of 12"

Work started: 3-6-1965. Completed: 4-24-1965
Date well drilling machine moved off of well: 4-24-65

(13) PUMP:
Manufacturer's Name: Layne & Bowler
Type: 1/2" bore H.P. 50

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME: Milo Schneider Exp Co (Person, firm or corporation)
Address: Rt. 1 Box 97, St Paul, Ore (Type and print)
Drilling Machine Operator's License No. 212
[Signed] Milo Schneider (Water Well Contractor)
Contractor's License No. 387 Date: 4-27-1965