

WATER WELL REPORT
STATE OF OREGON

MARION

RECEIVED

State Well No. 35/10-32 cd
FEB 17 1982

WATER RESOURCES DEPT
SALEM, OREGON

(1) OWNER:
Name Butteville Community Church
Address 10831 Arndt Rd. N.E.
City Aurora State Or.

(2) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL: Rotary Air Driven
Rotary Mud Dug
 Bored

(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other
Thermal: Withdrawal Reinjection

CASING INSTALLED: Steel Plastic
Threaded Welded
6" Diam. from 0 ft. to 100 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
2" Diam. from 90 ft. to 210 ft. Gauge .188

(6) PERFORATIONS: Perforated? Yes No
Type of perforator used Torch
Size of perforations 8 in. by 1/4 in.
6 perforations from 197 ft. to 202 ft.
10 perforations from 204 ft. to 209 ft.

(7) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
pump test made? Yes No If yes, by whom? Driller
d: 18 gal./min. with 22 ft. drawdown after 1 hrs.
Air test gal./min. with drill stem at ft. hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION: Special standards: Yes No
Well seal—Material used Cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 15 sacks
How was cement grout placed? Pressure grouted from 20 ft. to land surface.
Was pump installed? Yes Type Sub HP 1 1/2 Depth 189 ft.
Was a drive shoe used? Yes No Plugs Size: location ft.
Did any strata contain unusable water? Yes No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? Yes No Size of gravel: ft.
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number 205
SE 1/4 SW 1/4 Section 32 T. 3S R. 1W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 10831 Arndt Rd. N.E.
Aurora, Or.

(11) WATER LEVEL: Completed well.
Depth at which water was first found 197 ft.
Static level 52 ft. below land surface. Date 1/26/82
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 6"
Depth drilled 210 ft. Depth of completed well 210 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	2	
Clay, brown	2	28	
Clay, sand, blue, fine	28	52	
Clay, red	52	93	
Clay, brown	93	179	
Clay, blue	179	197	
*Sandstone, brown, broken	197	202	
Clay, blue	202	204	
*Sandstone, brown, broken	204	209	
Clay, blue	209	210	

Work started 1/15 19 82 Completed 1/26 1982
Date well drilling machine moved off of well 1/26 1982

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Bob Run Date 1/27, 19 82
(Drilling Machine Operator)
Drilling Machine Operator's License No. 994

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name B & G Drilling (Type or print)
(Person, firm or corporation)
Address 10030 S. Macksburg Rd. Canby, Or.
[Signed] George J. Wainwright
(Water Well Contractor)
Contractor's License No. 637 Date 1/27, 1982

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date of well completion.

SP*12658-690

Marvin Skyles called 2-12-91
Saying this log should be
in Marion Co. T 35/1W/32bd.