

**NOTICE TO WATER WELL CONTRACTOR**

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310

within 30 days from the date of well completion.

**WATER WELL REPORT**

STATE OF OREGON

(Please type or print)  
(Do not write above this line)

**STATE ENGINEER  
SALEM, OREGON**

State Well No. 4/2w-14

State Permit No. 1173

**(1) OWNER:**

Name Milton Hungsberg  
Address RT 1, Woodburn, ORE

**(2) TYPE OF WORK (check):**

New Well  Deepening  Reconditioning  Abandon   
If abandonment, describe material and procedure in Item 12.

**(3) TYPE OF WELL:**

Rotary  Driven   
Cable  Jetted   
Dug  Bored

**(4) PROPOSED USE (check):**

Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

**(5) CASING INSTALLED:**

Threaded  Welded   
12 " Diam. from 0 ft. to 19.5 ft. Gage 250  
12 " Diam. from 0 ft. to 12.3 ft. Gage 250  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

**PERFORATIONS:**

Perforated?  Yes  No.

Type of perforator used mill slot torch  
Size of perforations 3/6 in. by 2 1/2 in.  
9.60 perforations from 7.1 ft. to 11.3 ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
torch perforations from 1/8 x 1 ft ft. to \_\_\_\_\_ ft.  
60 perforations from 8.113 ft. to 12.3 ft.

**(7) SCREENS:**

Well screen installed?  Yes  No

Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

**(8) WATER LEVEL: Completed well.**

Static level 27 ft. below land surface Date 9-29-67  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

**(9) WELL TESTS:**

Drawdown is amount water level is lowered below static level

Was a pump test made?  Yes  No If yes, by whom? Driller  
Flow: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
330 " 33 " 6 "  
750 " 63 " 40 "  
Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water  Was a chemical analysis made?  Yes  No

**(10) CONSTRUCTION:**

Well seal—Material used Cement  
Depth of seal 19 ft.  
Diameter of well bore to bottom of seal 27 in.  
Were any loose strata cemented off?  Yes  No Depth \_\_\_\_\_  
Was a drive shoe used?  Yes  No  
Did any strata contain unusable water?  Yes  No  
Type of water? \_\_\_\_\_ depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_  
Was well gravel packed?  Yes  No Size of gravel: 3 round  
Gravel placed from 0 ft. to 12.3 ft.

**(11) LOCATION OF WELL:**

County Marion Driller's well number \_\_\_\_\_  
1/4 1/4 Section T. R. W.M.

Approx. kind and distance from section or subdivision corner

3000 N. 500 E. of S. W cor of sec 24, T. 45, R. 2 W.

**(12) WELL LOG:**

Diameter of well below casing 0

Depth drilled 123 ft. Depth of completed well \_\_\_\_\_ ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
Top soil brn	0	1	
Clay brn	1	22	
Clay sandy brn	22	46	
Sand fine, brn	46	49	
Clay sandy brn	49	65	
Sand grey med	65	100	
Sand grey med with small gravel	100	105	
Clay grey	105	123	

Work started 9-19 1967 Completed 9-29 - 1967

Date well drilling machine moved off of well 9-25 1967

**Drilling Machine Operator's Certification:**

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.

[Signed] C. E. Stadel Date 9-30, 1967  
(Drilling Machine Operator)

Drilling Machine Operator's License No. 84

**Water Well Contractor's Certification:**

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME A. STADELSONS  
(Person, firm or corporation) (Type or print)

Address RT 3 BOX 169 SILVERTON ORE

[Signed] Paul R. Stadel  
(Water Well Contractor)

Contractor's License No. 296 Date 9/30, 1967