
NOTICE TO WATER WELL OF The original and set of this report are to filed with the

WATER WELL REPORT M

STATE OF OREGON



STATE ENGINEER, SALET OREGON 97310 (Please ty)	pe or print) above this line) State Permit No.	0	
(1) OWNER:	(11) LOCATION OF WELL:		
Name DARYL W-LITCHFIELD	County MIRION Driller's well nu		
Address Rt. 4 BOX 20 A. SALEM ORE	34 14 Section /2 T. 8	5 R. 3W	W.M.
(2) TYPE OF WORK (check):	Bearing and distance from section or subdivision	n corner	
New Well Deepening □ Reconditioning □ Abandon □			
If abandonment, describe material and procedure in Item 12.			
(3) TYPE OF WELL: (4) PROPOSED USE (check):			e e
Botom: M. Duissen Cl	(12) WELL LOG: Diameter of well below casing		
Cable	Depth drilled 3// ft. Depth of compl	eted well 3//	ft.
CASING INSTALLED: Threaded Welded 2,	Formation: Describe color, texture, grain size and show thickness and nature of each stratu with at least one entry for each change of form in position of Static Water Level as drilling pro	m and aquifer pen nation. Report each	netr ated, change
ft. Gage	MATERIAL	From To	swl
ft. toft. Gage	TOPSOIL	0 16"	
(6) PERFORATIONS: Perforated? ☐ Yes No.	CLAY RED	1.6" 3'	
be of perforator used	BASALT WEATHERED	3' 35	
	BOULDER	35 37	
Size of perforations in. by in.	CLAY RED. STRKY	37 65	
perforations fromft. toft.	BASALT WEATHERED HARD	65 80	
perforations from ft. to ft.	BASHLT	80 82	
perforations from ft. to ft.	BASDLT WERTHERED HARD	82 93	
perforations from ft. to ft.	BASALT DENSE	148 169	
	BASBIT DENSE	169 176	
(7) SCREENS: Well screen installed? Yes XNo	BASALT SEANY	176 210	
Manufacturer's Name	BASALT DENSE	210 271	
Type Model No.	BASALT SCAMY	271 305	94'
Diam. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.	BASALT DENSE	305- 311	
(8) WATER LEVEL: Completed well.			
Static level 44' ft. below land surface Date 4-2-7/			
lbs. per square inch Date			
(9) WELL TESTS: AIR Drawdown is amount water level is lowered below static level.	, , , , , , , , , , , , , , , , , , , ,		
JNEED			
	Work started 3-25 197/ Complete	ted 4-2-	19 7
Yield: 60 gal./min. with 2/5 ft. drawdown after 2 hrs.	Date well drilling machine moved off of well	41- B	19 7
	Delition Management Continues Contin	7	
" " " "	Drilling Machine Operator's Certification: This well was constructed under my d		. Mate-
Bailer test gal./min. with ft. drawdown after hrs.	rials used and information reported abo		
Artesian flow g.p.m. Date	knowledge and belief.	11 0	
Temperature of water 57 Was a chemical analysis made? [] Yes X No	[Signed] (Drilling Machine Operator)	Date 4/- 2	., 19/
(10) CONSTRUCTION:	Drilling Machine Operator's License No.	187	
Well seal—Material used WELL JELL	Diffing Machine Operator's License No.		
Depth of seal 99' tt.	Water Well Contractor's Certification:		
Diameter of well bore to bottom of seal	This well was drilled under my jurisd	iction and this re	eport is
Were any loose strata cemented off? 🖸 Yes 💢 No Depth	true to the best of my knowledge and beli NAME J. A. SNEED & SOM		
Was a drive shoe used? Yes No	(Person, firm or corporation)	(Type or print)	
Did any strata contain unusable water? Yes No	Address 3910 SILVERTON	RO SALAK	. ar
Type of water? depth of strata	OAD 1	/	
Method of sealing strata off	[Signed] St. Sulley		
Was well gravel packed? [] Yes X No Size of gravel:	(Water Well Contra	_	
Gravel placed from ft. to ft.	Contractor's License No Date	4.2-	1971