

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED

FEB 19 1966 WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

STATE ENGINEER STATE OF OREGON (Please type or print) SALEM, OREGON

State Well No. 8/3w-14 L

State Permit No.

(1) OWNER:

Name REFORESTATION SERVICES INC.

Address 4280 Commercial St S E SALEM, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number NE 1/4 SW 1/4 Section 14 T. 8S R. 3W W.M. Bearing and distance from section or subdivision corner 1400' N and 1200' E on SW Cor Sec 14 Comm. St S. of Fabry Rd.

(3) TYPE OF WORK (check):

New Well [X] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [X] Industrial [] Municipal [] Irrigation [] Test Well [] Other []

(5) TYPE OF WELL:

Rotary [] Driven [] Cable [X] Jetted [] Dug [] Bored []

(6) CASING INSTALLED:

Threaded [] Welded [X]

6" Diam. from 0 ft. to 56 ft. Gage .280

(7) PERFORATIONS:

Perforated? [] Yes [X] No

Type of perforator used

Size of perforations in. by in. perforations from ft. to ft.

(8) SCREENS:

Well screen installed? [] Yes [X] No

Manufacturer's Name Type Model No. Slot size Set from ft. to ft. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Cement and bentonite Depth of seal 36 ft. Was a packer used? no Diameter of well bore to bottom of seal 10 in. Were any loose strata cemented off? [] Yes [X] No Depth Was a drive shoe used? [X] Yes [] No Was well gravel packed? [] Yes [X] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [X] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 2.75 ft. below land surface Date 1/14/65 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? [] Yes [] No If yes, by whom? Yield: gal./min. with ft. drawdown after hrs. Bailer test 35 gal./min. with 30 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 61 ft. Depth of completed well 61 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with 3 columns: MATERIAL, FROM, TO. Rows include Clay-surface, Clay-red, Clay-tan, Lava-volcanic ash, lava-basalt, black, and Aquifer 56 to 60.

Work started 1/13 1965. Completed 1/14 1965 Date well drilling machine moved off of well 1/15 1965

(13) PUMP: not installed

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME DUFFIELD BROS (Person, firm or corporation) (Type or print)

Address 4123 BLUFF AVE S E, SALEM, ORE.

Drilling Machine Operator's License No. 47

[Signed] Howard Duffield (Water Well Contractor)

Contractor's License No. 15 Date Jan 18 1965