

MARI..1200

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 4/24-17Q1 State Permit No. G3024

(1) OWNER:

Name: Walter Wilmer Address: Aurora

(2) LOCATION OF WELL:

County: Marion Driller's well number: SW 1/4 SE 1/4 Section 17 T. 4S R. 2 W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well [X] Deepening [] Reconditioning [] Abandon [] If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [] Test Well [] Other [] Rotary [X] Driven [] Cable [] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

16" Diam. from 0 ft. to 20 ft. Gage 250 12" Diam. from 0 ft. to 150-8" ft. Gage 250

(7) PERFORATIONS:

Perforated? [X] Yes [] No Type of perforator used: torch Size of perforations 7/16 in. by 8 in. 720 perforations from 90-8 ft. to 150 ft. 84 perforations from 68 ft. to 75 ft.

(8) SCREENS:

Well screen installed [] Yes [] No Manufacturer's Name: Type: Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal: Concrete Depth of seal: 20 ft. Was a packer used? Diameter of well bore to bottom of seal: 24 in. Were any loose strata cemented off? [] Yes [X] No Depth: Was a drive shoe used? [] Yes [X] No Was well gravel packed? [X] Yes [] No Size of gravel: 3/8-3/4 Gravel placed from 0 ft. to 148 ft. Did any strata contain unusable water? [] Yes [X] No Type of water? Depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level: 40 ft. below land surface Date: 11-18-63 Artesian pressure: lbs. per square inch Date: 2-7-63

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [] Yes [] No If yes, by whom? Yield: 1200 gal./min. with 86 ft. drawdown after 8 hrs. 816 " 45 " 8 1/2 " 575 " 20 " 9 "

(12) WELL LOG:

Diameter of well below casing: 0 Depth drilled: 150 ft. Depth of completed well: 150 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Entries include: Top soil (0-2), Brown clay (2-28), Gray clay hard with small pebbles of soft silt (28-42), extra hard gray clay (42-46), gray clay (46-65), fine sand (65-75), Brown clay (75-95), Black sand (95-112), gray clay (112-131), 16 black sand (131-136), gravel (136-148), Brown clay (148-150)

Work started: 2-7-63 Completed: 11-30-63 Date well drilling machine moved off of well: 11-30-63

(13) PUMP:

Manufacturer's Name: Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME: Milo Schmidt & Co. (Person, firm or corporation) Address: Star Route Box 97 St Paul

Drilling Machine Operator's License No.: 212

[Signed]: Milo Schmidt (Water Well Contractor)

Contractor's License No.: 387 Date: 11-30-63

Legal Description of Walter Wilmes St. Paul Farm

R2W Willamette Meridian T 4S in Marion County, Oregon, which Northeast Corner is 58 links S. and 1.60 Ch. West of N.E. corner of the S. E. 1/4 Section of 17 in said township and range; thence S. 38.20 Ch. thence S. $87^{\circ} - 30'$ West 40.04 Chains thence N. 39.65 Ch. thence S. $89^{\circ} 15'$ E. 39.97 Ch to the place of beginning and containing approximately 155.77 acres.

Well is located approximately 1260' N. and 840' East of the S. E. corner of above property.