

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the

WATER RESOURCES DEPARTMENT,
SALEM, OREGON 97310
within 30 days from the date
of well completion.

RECEIVED
STATE OF OREGON
NOV 15 1978
(Please type or print)
WATER RESOURCES DEPT.
SALEM, OREGON

MARI... (12/19/78)
State Well No. 85/3W-2046
State Permit No. G-8288

(1) OWNER:

Name ROBERT J HILL
Address 6540 ELKHURST AVE S.E.
SALEM OREGON

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Cable Dug
Driven Jetted Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
6" Diam. from +1 ft. to 79 ft. Gage 1250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(6) PERFORATIONS:

Perforated? Yes No.
Type of perforator used TORCH
Size of perforations 1/4 in. by 12 in.
28 perforations from 50 ft. to 78 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " " " "
" " " " " "
AIR
Better test 55 gal./min. with 20 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m.
Temperature of water 53 Depth artesian flow encountered _____ ft.

(9) CONSTRUCTION:

Well seal—Material used CEMENT
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 5 sacks
How was cement grout placed? MIXED AND PAVED

Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 1/2
Gravel placed from 20 ft. to 79 ft.

(10) LOCATION OF WELL:

County MARION Driller's well number _____
NW 1/4 SW 1/4 Section 20 T. 85 R. 3W W.M.
Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found _____ ft.
Static level 24 ft. below land surface. Date _____
Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 79 ft. Depth of completed well 79 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP Soil RED	0	2	
CLAY RED	2	21	
CLAY LIGHT BROWN	21	47	
DECOMPOSED BASALT	47	79	24

Work started 10/12 1978 Completed 10/18 1978
Date well drilling machine moved off of well 10/18 1978

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Edmund Harrison Date _____, 19____
(Drilling Machine Operator)
Drilling Machine Operator's License No. 842

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name BELLO WELL DRILLING
(Person, firm or corporation) (Type or print)
Address 4783 COLONA DR S.E. SALEM
[Signed] Paul Bello
(Water Well Contractor)
Contractor's License No. 579 Date 11/5, 1978