STATE ENGINEER Salem, Oregon Well Record	STATE WELL NO. 4/2W-19C(1) COUNTY Marion APPLICATION NO. GR-895		
OWNER: C. James Gooding ADDRESS: CITY AND	St. Paul, Oregon		
LOCATION OF WELL: Owner's No STATE:	© (1)		
Depth drilled140	Section19		
FINISH:  Liner 12' x 8" perforations 7' on bottom Perforations ¼" x 2" slots  AQUIFERS:  Black sand and gravel 280 gallons per minute 136 - 140	) feet		
WATER LEVEL: 37 feet 5/12/52			
PUMPING EQUIPMENT: Type Peerless Line shaft turbine 6 Capacity	5" col. H.P. 15 Elec.		
WELL TESTS: Drawdown 40 ft. after hours 280 Drawdown ft. after hours			
USE OF WATER Irrigation 66 acres Temp. 55 °F SOURCE OF INFORMATION Owner DRILLER or DIGGER J. T. Miller ADDITIONAL DATA:	•		

REMARKS:

## STATE ENGINEER Salem, Oregon

State Well No.	4/2W-19C(1)
County	Marion
Application No	GR-895

## Well Log

Owner: C. James Gooding	Owner's No	1		
Driller: J. T. Miller	Date Drilled			
	(Feet below land surface)		Thickness	
CHARACTER OF MATERIAL	From	То	(feet)	
Surface and clay	0	98	98	
Sand and a little water	98	101	3	
Green clay	101	104	3	
Gray clay	104	112	8	
Muddy sand	112	119	7	
Sand and gravel	119	128	9	
Clean gravel (test 165 gpm)	128	129	1	
Gravel muddy & tight	129	133	4	
Clean gravel (test 175 gpm)	133	134	11	
Muddy gravel	134	135	1	
Clay	135	136	11	
Black sand and gravel (test 280 gpm)	136	140	4	
			1	