

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date
of well completion.

WATER WELL RECORD

STATE OF OREGON

(Please type or print)

(Do not write above this line)

RECEIVED

MAR 30 1977

State Well No.

Permit No.

SALEM, OREGON

(1) OWNER:

Name JAMES GILKINSON

Address 405 85TH ST. SE
SALEM ORE 97301

(2) TYPE OF WORK (check):

New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐

If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary ☒ Driven ☐
Cable ☐ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):

Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED:

Threaded ☐ Welded ☒ 1/4"

6" Diam. from 0 ft. to 23 ft. Gage 1/4"

" Diam. from " ft. to " ft. Gage "

" Diam. from " ft. to " ft. Gage "

(6) PERFORATIONS:

Perforated? ☐ Yes ☒ No.

Type of perforator used

Size of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

(7) SCREENS:

Well screen installed? ☐ Yes ☒ No

Manufacturer's Name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is
lowered below static level

Was a pump test made? ☒ Yes ☐ No If yes, by whom? SNED

AIR
d: 16 gal./min. with 133'4" drawdown after 1 hrs.

" " " "

" " " "

Bailer test gal./min. with ft. drawdown after hrs.

Artesian flow g.p.m.

Temperature of water 53 Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used BENTONITE

Well sealed from land surface to 23 ft.

Diameter of well bore to bottom of seal 10 in.

Diameter of well bore below seal 6 in.

Number of sacks of cement used in well seal NONE sacks

Number of sacks of bentonite used in well seal 1 1/2 sacks

Brand name of bentonite WELL TELL

Number of pounds of bentonite per 100 gallons

of water 100 lbs./100 gals.

Was a drive shoe used? ☐ Yes ☒ No Plugs NO Size: location ft.

Did any strata contain unusable water? ☐ Yes ☒ No

Type of water? depth of strata

Method of sealing strata off

Was well gravel packed? ☐ Yes ☒ No Size of gravel: ft.

Gravel placed from ft. to ft.

(10) LOCATION OF WELL:

County MARION Driller's well number

1/4 SW 1/4 Section 24 T. 8S R. 3W W.M.

Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.

Depth at which water was first found 37' ft.

Static level 26'8" ft. below land surface. Date 3/26/77

Artesian pressure lbs. per square inch. Date

(12) WELL LOG:

Diameter of well below casing 6"

Depth drilled 160' ft. Depth of completed well 160 ft.

Formation: Describe color, texture, grain size and structure of materials;
and show thickness and nature of each stratum and aquifer penetrated,
with at least one entry for each change of formation. Report each change in
position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
TOP SOIL	0	2	
BASALT WEATHERED	2	9	
CLAY GRAY STICKY	9	10	
SANDSTONE GRAY	10	37	
LIMESTONE	37	41	26'8"
SANDSTONE GRAY	41	72	
LIMESTONE	72	75	
CLAYSTONE BLUE STICKY	75	89	
SANDSTONE	89	96	
CLAYSTONE BLUE FIRM	96	111	
SANDSTONE	111	160	26'8"

Work started 3/25 1977 Completed 3/26 1977

Date well drilling machine moved off of well 3/26 1977

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision.
Materials used and information reported above are true to my
best knowledge and belief.

[Signed] James R. Sned Date 3/28, 1977
(Drilling Machine Operator)

Drilling Machine Operator's License No. 941

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is
true to the best of my knowledge and belief.

Name J.A. SNED & SONS
(Person, firm or corporation) (Type or print)

Address 4700 ELIZABETH N. SALEM ORE

[Signed] J.A. Sned
(Water Well Contractor)

Contractor's License No. 6 Date 3-28, 1977