

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

RECEIVED WATER WELL REPORT
STATE OF OREGON

JUN 7 1960

State Well No. 4/2W-21H(1)

State Permit No. _____

(1) OWNER:

Name George S. Flick
Address 2507 N. E. 63rd Ave. Portland 13, Oregon

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
SE 1/4 NE 1/4 Section 21 T. 4S R. 2 W.M.
Bearing and distance from section or subdivision corner
199' N of H corner
1005' E of H corner
75' W & 149' N from E 1/4 cor
sec. 21

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
20" Diam. from 0 ft. to 21' cemented
16" Diam. from 0 ft. to 90' Gage
12" Diam. from 0 ft. to 126' Gage

(7) PERFORATIONS:

Perforated? Yes No
Type of perforator used mill knife and torch
SIZE of perforations in. by in.
torched perforations from 16 in. 5 ft. above shoe
!!! perforations from 12 in. 4 ft. to 126' ft.
mil, k, perforations from 12 pipe 75 ft. to 85' zig zag
250 perforations from 1" 91 ft. to 120' "!!! ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel: 1/4 minus
Gravel placed from 0 ft. to 126 ft.
Was a surface seal provided? Yes No To what depth? _____ ft.
Material used in seal— cement
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level _____ ft. below land surface Date _____
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:

[Signed] George S. Flick Date June 2, 1960
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom J. T. Miller
Yield: 400 gal./min. with 25 ft. drawdown after _____ hrs.
" 600 " 58 " " "
" 1000 " 85 " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow 125 g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well _____ inches.
Depth drilled 126 ft. Depth of completed well 126 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
surface	0	2
yellow sandy clay	2	8
grey clay	8	18
surface sand, water	18	22
grey clay	22	40
sand and water	40	46
grey clay	46	85
black sand, water	85	90
blue clay	90	95
brown sand, water	95	100
blue clay	100	101
black sand, water	101	105
gravel, water	105	116
blue clay	116	117
black sand gravel, water	117	125
blue clay.	125	126

Work started 5-4 1960. Completed 6-1st 1960

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME J. T. Miller
(Person, firm, or corporation) (Type or print)

Address Box 198, Aurora Ore.

Driller's well number _____

[Signed] J. T. Miller
(Well Driller)

License No. 7 Date 6-1st, 1960.