

RECEIVED
MAR 30 1965

MAR 30 1965
12608

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON
within 30 days from the date
of well completion.

STATE ENGINEER
SALEM OREGON
WATER WELL REPORT
STATE OF OREGON
(Please type or print)

State Well No. 8/3W-26 #bd
State Permit No.

(1) OWNER:
Name BAYLA W. Gilmore
Address OLD PACIFIC Hwy. JEFFERSON OREG.

(2) LOCATION OF WELL:
County MAXION Driller's well number
1/4 Section N.41.24 T. 8. S. R. 3 W. W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
6" Diam. from +1 ft. to 1.77 ft. Gage 2.50
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used _____
Size of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed? Yes No
Manufacturer's Name _____ Model No. _____
Diam. Slot size Set from _____ ft. to _____ ft.
Diam. Slot size Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Well seal—Material used in seal DRILL CUTTING & BENTONITE
Depth of seal 1.75 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusuable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 181 ft. below land surface Date 3/23/65
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " " "
AIR " " " " " "
Pump test 12 gal./min. with 132 ft. drawdown after 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 336 ft. Depth of completed well 336 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
CLAY STONE (RED)	0	40
" " YELLOW	40	120
" " RED	120	174
BASALT Rock	174	265
CLAY STONE - BLACK	265	268
" " - WHITE	268	281
SAND STONE - Brown	281	284
BASALT Rock	284	320
CLAY STONE - BLACK	320	336

Work started 3/19/65 19 Completed 3/23/65 19
Date well drilling machine moved off of well _____ 19

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____
Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME WILLIAM ROBINSON & WREST
(Person, firm or corporation) (Type or print)
Address 5545 JOSEPH ST. S.E.
Drilling Machine Operator's License No. 59
[Signed] William R. Miller
(Water Well Contractor)
Contractor's License No. 37 Date 3/25/65 19