

MARI....

12609

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

RECEIVED
JAN 5 1966
STATE ENGINEER

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion

STATE OF OREGON
(Please type or print)

State Well No. 8/3w-26bd
State Permit No.

(1) OWNER: SYSTEM OREGON
Name Gayle W. Gilmore
Address Old Pacific Hwy. Jefferson OR

(2) LOCATION OF WELL:
County Marion Driller's well number
1/4 Section N.W. 26. 8, S R. 3, W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check): Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED: Threaded Welded
6" Diam. from 0 ft. to 90 ft. Gage 1350

(7) PERFORATIONS: Perforated? Yes No
Type of perforator used
Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS: Well screen installed? Yes No
Manufacturer's Name
Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Well seal—Material used in seal DRILL CUTTINGS + Bentonite
Depth of seal 8.5 ft. Was a packer used? NO
Diameter of well bore to bottom of seal 9.5 in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 60 ft. below land surface Date 5/9/65
Artesian pressure lbs. per square inch Date

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
AIR " " " "
test 14 gal./min. with 7.5 ft. drawdown after 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well below casing 6
Depth drilled 147 ft. Depth of completed well 147 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top Soil	0	4
ORANGE CLAY	4	20
RED "	20	50
ORANGE "	50	70
RED COMPACTED ROCK	70	89
BASALT "	89	140
Blue CLAY STONE	140	147

Work started 5/9/65 19 Completed 5/9/65 19
Date well drilling machine moved off of well " " " 19

(13) PUMP:
Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME William Robinson + West
(Person, firm or corporation) (Type or print)
Address 5545 Joseph St. S.E.
Drilling Machine Operator's License No. 59
[Signed] William P. Miller
(Water Well Contractor)
Contractor's License No. 37 Date 5/14/65, 19