

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

RECEIVED

WATER WELL REPORT
STATE OF OREGON

State Well No. 8/3W-29G

State Permit No. G-1746

MAY 13 1960

(1) OWNER:

Name H. R. Jones
Address Rt. 3

STATE ENGINEER
SALEM, OREGON

(2) LOCATION OF WELL:

County Marion Owner's number, if any—
1/4 Section 29 T. 8 R. 3W W.M.
Bearing and distance from section or subdivision corner
2000' S & 1600' W
from NE corner Sect. 29

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 2.5 ft. Gage 28.0
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
SIZE of perforations in. by in.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed Yes No

Manufacturer's Name _____ Model No. _____
Type _____ Slot size _____ Set from _____ ft. to _____ ft.
Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Was well gravel packed? Yes No Size of gravel. _____
Gravel placed from _____ ft. to _____ ft.
Was a surface seal provided? Yes No To what depth? 24 ft.
Material used in seal—Graduated crushed rock
Did any strata contain unusable water? Yes No Drillings
Type of water? Surface Depth of strata to 24'
Method of sealing strata Backfill around casing

(10) WATER LEVELS:

Static level 37 ft. below land surface Date 5/11/60
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by: _____

[Signed] H. R. Jones Date 5/11, 1960
(Owner)

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Statten Supply
Yield: 3.5 gal./min. with 9.0 ft. drawdown after 4 hrs.

Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well 8" top 37'
6" balance inches.

Depth drilled 137 ft. Depth of completed well 137 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Red topsoil	0	1
Tan clay-like material	1	9
soft and sticky		
obvious shading of	9	2.5
blue clay - rattled below		
and brissh.		
Very hard grey basalt	2.5	62
Softer black rock -	62	91
some layers partly		
decomposed and casing		
(56 PM at 65')		
Hard black basalt	91	125
Seamy - broken black	125	127
rock - showing an evidence		
of open formation		
(aquifer)		
Hard, very black rock	127	137

Work started 4/25 1960 Completed 5/11 1960

(13) PUMP:

Manufacturer's Name _____ Type: _____ H.P. _____

Well Driller's Statement:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WEST WELL DRILLING
(Person, firm, or corporation) (Type or print)

Address 4098 MARKET ST. N.E. SALEM

Driller's well number _____

[Signed] Marion E. West
(Well Driller)

License No. 30 Date 5/11, 1960