RECEIVED AUG 7 1981 WATER RESOURCES DEPT SALEM, OREGON

RECEIVED JUL 24 1981 WATER RESOURCES DEPT SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

State Well No. 8S/3W-30CC

State Permit No. .....

12795

(1) OWNER:
Name Don Vorreshies
Address 8611 NE 17th St.
City Bellevue State WA

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary Air ☒ Driven ☐
Rotary Mud ☐ Dug ☐
Cable ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐
Thermal: Withdrawal ☐ Reinjection ☐

CASING INSTALLED:
Steel ☒ Plastic ☐
Threaded ☐ Welded ☒
6" Diam. from +1 ft. to 99 ft. Gauge .250
" Diam. from ft. to ft. Gauge

LINER INSTALLED:
" Diam. from ft. to ft. Gauge

(6) PERFORATIONS:
Perforated? ☒ Yes ☐ No
Type of perforator used Torch cut
Size of perforations 3/16 in. by 16 in.
36 perforations from 60 ft. to 99 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS:
Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot Size Set from ft. to ft.
Diam. Slot Size Set from ft. to ft.

(8) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " "
Air test 30 gal./min. with drill stem at 100 ft. 1 hrs.
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water 55 Depth artesian flow encountered ft.

CONSTRUCTION:
Special standards: Yes ☐ No ☒
Well seal—Material used cement
Well sealed from land surface to 20 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 10 in.
Number of sacks of cement used in well seal 9 sacks
How was cement grout placed? From bottom to top
Was pump installed? No Type HP Depth ft.
Was a drive shoe used? ☐ Yes ☒ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of Water? depth of strata
Method of sealing strata off
Was well gravel packed? ☒ Yes ☐ No Size of gravel: 1/2 pea
Gravel placed from 20 ft. to 99 ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
SW ¼ SW ¼ Section 30 T. 8S R. 3W W.M.
Tax Lot # Lot Blk Subdivision
Address at well location: 7234 Skyline Drive
Salem, Oregon

(11) WATER LEVEL: Completed well.
Depth at which water was first found 64 ft.
Static level 16 ft. below land surface. Date 7/21/81
Artesian pressure lbs. per square inch. Date

(12) WELL LOG:
Diameter of well below casing 6
Depth drilled 100 ft. Depth of completed well 100 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
Top soil	0	3	
Red clay	3	6	
Yellow clay	6	12	
Red clay	12	16	
Gray clay stone (soft)	16	26	
Gray clay	26	37	
Gray clay stone (soft)	37	57	
Brown sandy clay stone (soft)	57	67	
Brown sandstone (soft)	67	100	16

Work started 7/20 1981 Completed 7/20 1981
Date well drilling machine moved off of well 7/21/ 1981

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] George M. Simpson (Drilling Machine Operator) Date 7/22, 1981
Drilling Machine Operator's License No. 1072

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name Schoen Electric, Inc. (Person, firm or corporation) (Type or print)
Address 626 W. Queen Ave., Albany, OR 97321
[Signed] (Water Well Contractor)
Contractor's License No. 513 Date 7/22, 1981

NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the WATER RESOURCES DEPARTMENT, SALEM, OREGON 97310 within 30 days from the date of well completion.

SP*12658-690