ORIGINAL File Original, and Duplicate with the STATE ENGINEER, SALEM, OREGON

WATER WELL DRILLERS REPORT

STATE OF OREGON

Do Not Fill In — State Well No. 8/3W-32 G(1) — State Permit No. G

(1) OWNER:
Name T B Gutschalk
Address R 3 Box 773 Salem Ore

(2) LOCATION OF WELL:
County MARION Owner's number, if any—
R. F. D. or Street No.
Bearing and distance from section or subdivision corner
Section 32 in Township 8 South, Range 3 West of Willamette Meridian

(3) TYPE OF WORK (check):
New well ☑ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) EQUIPMENT:
Rotary ☐
Cable ☑
Dug Well ☐

(6) CASING INSTALLED:
Threaded ☐ Welded ☑

FROM	ft. to	ft.	Diam.	Gage or Wall
0	108	6"	.237	

Type and size of shoe or well ring none
Describe joint

If gravel packed

Diameter of Bore	from ft.	to ft.
8"	0	108

Size of gravel: 3/4

(7) PERFORATIONS:
Type of perforator used Cutting Torch
SIZE of perforations 1/16 in., length, by 1/4 in.
FROM 93 ft. to 108 ft. 1 perf per foot 4 No. of rows

SCREENS:
Give Manufacturer's Name, Model No. and Size

(8) CONSTRUCTION:
Was a surface sanitary seal provided? ☑ Yes ☐ No To what depth 40 ft.
Were any strata sealed against pollution? ☐ Yes ☐ No
If yes, note depth of strata

FROM	ft. to	ft.
"	"	"

METHOD OF SEALING Sand over gravel backfill

(9) WATER LEVELS:

Depth at which water was first found	31 ft.
Standing level before perforating	31 ft.
Standing level after perforating	31 ft.

Log Accepted by:
[Signed] T B Gutschalk Owner Dated Aug 26, 1956

(10) WELL TESTS:
Was a pump test made? ☐ Yes ☑ No If yes, by whom?

Yield:	gal./min. with	ft. draw down after	hrs.
"	"	"	"
"	"	"	"

Artesian flow g.p.m.
Shut-in pressure lbs. per square inch.
Bailer test 25 g.p.m. with 57 ft. drawdown
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No
Was electric log made of well? ☐ Yes ☑ No

(11) WELL LOG:
Diameter of well, 6 inches.
Total depth 108 ft. Depth of completed well 108 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

0 ft. to	31 ft.	Decomposed rock
31 "	50 "	Basalt boulders & decomposed rock
50 "	98 "	Hard decomposed rock
98 "	108 "	Hard black shale

RECEIVED
JUN 30 1958
STATE ENGINEER
SALEM, OREGON

Ground elevation at well site 960 feet above mean sea level.
Work started July 23 19 56 Completed Aug 1 19 56

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WEST WELL DRILLING (Person, firm, or corporation) (Typed or printed)
Address 4120 MARKET ST
Driller's well number
[Signed] Marion E. Nesset (Well Driller)
License No. 30 Dated Aug. 26, 1956