

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

RECEIVED
APR 15 1965
STATE ENGINEER

WATER WELL REPORT

STATE OF OREGON G-5585
 (Please type or print) G-3877

MAR. 1. 29/

State Well No. 4/2w-25N
 State Permit No. 3

(1) OWNER:

Name JAKE & ELIZABETH SONNEN
 Address RT. 1 BOX 147
AURORA, OREGON

(2) LOCATION OF WELL:

County MARION Driller's well number 1015
 1/4 Section T. R. W.M.
 Bearing and distance from section or subdivision corner
SEC. 25-26-36 T) WNSHIP 4 RANGE 2 W

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(6) CASING INSTALLED:

Threaded Welded
12 " Diam. from TOP ft. to 200 ft. Gage 250
 " Diam. from _____ ft. to _____ ft. Gage _____
 " Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used _____
 Size of perforations in. by _____ in.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____
 Type _____ Model No. _____
 _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal CEMENT & PUDDLE CLAY
 Depth of seal 20 ft. Was a packer used? _____
 Diameter of well bore to bottom of seal 14 in.
 Were any loose strata cemented off? Yes No Depth _____
 Was a drive shoe used? Yes No
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____

(10) WATER LEVELS:

Static level 25 ft. below land surface Date 4/8/65
 Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? DRILLER
 Yield: 400 gal./min. with 45 ft. drawdown after 16 hrs.
 " " " "
 " " " "
 Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
 Artesian flow g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 205 ft. Depth of completed well 205 ft.
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	5
CLAY	5	25
SAND	25	30
CLAY	30	50
SAND	50	60
CLAY	60	85
SAND	85	95
CLAY	95	110
SAND	110	120
CLAY	120	137
SAND	137	150
CLAY	150	162
SAND	162	180
CLAY	180	203
SAND	203	205

Work started MAR. 25 1965. Completed APRIL 8 1965
 Date well drilling machine moved off of well APRIL 9 1965

(13) PUMP:

Manufacturer's Name _____
 Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WILLAMETTE DRILLING CO
 (Person, firm or corporation) (Type or print)

Address RT. 2 BOX 276 SALEM, OREGON

Drilling Machine Operator's License No. 179

[Signed] Emil O. Bieer
 (Water Well Contractor)

Contractor's License No. 2 Date APRIL 9 1965