

NOTICE TO WATER WELL CONTRACTOR
The original and first copy
of this report are to be
filed with the
STATE ENGINEER, SALEM, OREGON
within 30 days from the date
of well completion.

MARI. 1307
RECEIVED
SEP 19 1969
STATE ENGINEER
SALEM, OREGON

RECEIVED See GR-310
OCT 10 1969
STATE ENGINEER
SALEM, OREGON
State Well No. 412W-26 ac
Permit No.

(1) OWNER:

Name John Holmes
Address 1504 333 Modburn Ave 97011

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
8" Diam. from 0 ft. to 123 1/2 ft. Gage 250
11" Diam. from 123 1/2 ft. to 124 1/2 ft. Gage 375
6" Diam. from 0 ft. to 20 ft. Gage 250

PERFORATIONS:

Perforated? Yes No.
Type of perforator used Mills Knife
Size of perforations 5/16 in. by 2 in.
120 perforations from 80 ft. to 90 ft.
320 perforations from 90 ft. to 120 ft.

(7) SCREENS:

Well screen installed? Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(8) WATER LEVEL: Completed well.

Static level 12 ft. below land surface Date 4-25-69
Artesian pressure _____ lbs. per square inch Date _____

(9) WELL TESTS:

Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom?
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
200" water lift "36" D.D. 4hr
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(10) CONSTRUCTION:

Well seal—Material used Bentonite, sand & clay
Depth of seal 20' ft.
Diameter of well bore to bottom of seal 16 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____
Was well gravel packed? Yes No Size of gravel: 3/4-9/8
Gravel placed from 21- ft. to 123 ft.

(11) LOCATION OF WELL:

County Marion Driller's well number _____
1/4 Section 26 T. 4S R. 2W W.M.
Bearing and distance from section or subdivision corner _____

(12) WELL LOG:

Diameter of well below casing _____
Depth drilled 124 ft. Depth of completed well 124 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level as drilling proceeds. Note drilling rates.

MATERIAL	From	To	SWL
was 12" concrete telescopic well to 72'			
Black sand	72	88	
Black sand and gravel	88	89	
Black sand	89	112	
Brown silty clay hard	112	118	
tan gravel and Brown sand	118	123	
Brown Clay	123	124	

Work started 4-8 1969 Completed 3-1- 69
Date well drilling machine moved off of well 4-30- 69

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Edgar J. Muller Date 5-15-69
(Drilling Machine Operator)
Drilling Machine Operator's License No. 581

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
NAME Mike Schneider Equip Co
(Person, firm or corporation) (Type or print)
Address Star Route, Box 99, H. Paul One
[Signed] Mike Schneider
(Water Well Contractor)
Contractor's License No. 387 Date 5-15 69