

1370
ARI.....

RECEIVED
AUG 25 1958
STATE ENGINEER
SALEM, OREGON

20-Dan Spoor

4/2W-26M(1)

File Original and
First Copy with the
STATE ENGINEER,
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
G-959

State Well No. _____
State Permit No. G815

(1) OWNER:
Name Neal W Miller
Address Rt. 1 Box 328
Woodburn Ore

(2) LOCATION OF WELL:
County Manon Owner's number, if any 4815
N. W. 1/4 Section 26 T. 42 R. 24 W.M.
Bearing and distance from section or subdivision corner
14 ch N. and 62 ch W. from
N. E. corner, Andrew Brown
D. R. C. 53

(3) TYPE OF WORK (check):
New Well Deepening Reconditioning Abandon
If abandonment, describe material and procedure in Item 11.

PROPOSED USE (check):
Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:
Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:
Threaded Welded
12" Diam. from 0 ft. to 8.5 ft. Gage 1/4" interval
8" Diam. from 0 ft. to 11.5 ft. Gage etc. B.K.
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:
Perforated? Yes No
Type of perforator used Torch
SIZE of perforations 1/8 in. by 2 1/2 in.
16 Per FT. perforations from 8.8 ft. to 10.5 ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.
perforations from _____ ft. to _____ ft.

(8) SCREENS:
Well screen installed Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
" Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:
Was well gravel packed? Yes No Size of gravel: 1/4 to 3/4
Gravel placed from 0 ft. to 10.5 ft.
Was a surface seal provided? Yes No To what depth? 9.5 ft.
Material used in seal— Earth
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata 7.9
Method of sealing strata off _____

(10) WATER LEVELS:
Static level 29' 9" ft. below land surface Date 8/18/58
Artesian pressure _____ lbs. per square inch Date _____

Log Accepted by:
[Signed] Neal W Miller Date 8-21, 1958
(Owner)

(11) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? Driller
Yield: 6.30 gal./min. with 78 ft. drawdown after 8 hrs.
" 5.00 " " 32 " " 8 "
" " " " " " " "
Bailer test gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow g.p.m. Date _____
Temperature of water 53 Was a chemical analysis made? Yes No

(12) WELL LOG: Diameter of well 12-10 inches.
Depth drilled 115 ft. Depth of completed well 105 ft.
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<u>Soil</u>	<u>0</u>	<u>2</u>
<u>Brown sandy clay</u>	<u>2</u>	<u>44</u>
<u>Brown clay</u>	<u>44</u>	<u>52</u>
<u>Blue clay</u>	<u>52</u>	<u>77</u>
<u>Dark gray sandy clay</u>	<u>77</u>	<u>87</u>
<u>Sand + water</u>	<u>87</u>	<u>105</u>
<u>Blue clay</u>	<u>105</u>	<u>115</u>

Work started 5/2/58 19 _____ Completed 8/19 1958

(13) PUMP:
Manufacturer's Name _____
Type: _____ H.P. _____

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME George Zent + Son
(Person, firm, or corporation) (Type or print)

Address 43.05 NE 4th St Vancouver

Driller's well number _____

[Signed] George Zent
(Well Driller)

License No. 228 Date 8/19, 1958