

# NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the STATE ENGINEER, SALEM 10, OREGON within 30 days from the date of well completion.

## WATER WELL REPORT

STATE OF OREGON  
(Please type or print)

State Well No. \_\_\_\_\_

State Permit No. \_\_\_\_\_

### (1) OWNER:

Name Neal Miller  
Address Formerly Edmund Williamson  
Woodback Ore

### (2) LOCATION OF WELL:

County Morion Driller's well number \_\_\_\_\_  
1/4 Section 27 T. 24 R. 4S W.M.  
Bearing and distance from section or subdivision corner \_\_\_\_\_

### (3) TYPE OF WORK (check):

New Well ☐ Deepening ☐ Reconditioning ☐ Abandon ☐  
Abandonment, describe material and procedure in Item 12.

### (4) PROPOSED USE (check):

Domestic ☐ Industrial ☐ Municipal ☐ Rotary ☐ Driven ☐  
Irrigation ☐ Test Well ☐ Other ☐ Cable ☐ Jetted ☐  
Dug ☐ Bored ☐

### (5) TYPE OF WELL:

### (6) CASING INSTALLED:

Threaded ☐ Welded ☐  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_  
" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft. Gage \_\_\_\_\_

### (7) PERFORATIONS:

Perforated? ☐ Yes ☐ No  
Type of perforator used \_\_\_\_\_  
Size of perforations in. by in.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

### (8) SCREENS:

Well screen installed ☐ Yes ☐ No  
Manufacturer's Name \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. Slot size Set from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

### (9) CONSTRUCTION:

Well seal—Material used in seal \_\_\_\_\_  
Depth of seal \_\_\_\_\_ ft. Was a packer used? ☐ Yes ☐ No  
Diameter of well bore to bottom of seal \_\_\_\_\_ in.  
Were any loose strata cemented off? ☐ Yes ☐ No Depth \_\_\_\_\_  
Was a drive shoe used? ☐ Yes ☐ No  
Was well gravel packed? ☐ Yes ☐ No Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Did any strata contain unusable water? ☐ Yes ☐ No  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

### (10) WATER LEVELS:

Static level 37 ft. below land surface Date 6-23-63  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_

### (11) WELL TESTS:

Drawdown is amount water level is lowered below static level  
Was a pump test made? ☐ Yes ☐ No If yes, by whom?  
Yield: 1500 gal./min. with 51 ft. drawdown after \_\_\_\_\_ hrs.  
" " " " " "  
" " " " " "  
" " " " " "  
Bailer test gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made? ☐ Yes ☐ No

### (12) WELL LOG:

Diameter of well below casing \_\_\_\_\_  
Depth drilled \_\_\_\_\_ ft. Depth of completed well 148 ft.  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Went want to set a 50 h.p. Turbine well over 120' deep.		
We bailed sand to 148' swabbed it back in sand gravel		
Developed with air and swabbed 5 different days. run air between set test pump 8" column 9 1/2" lower 1/8" air line		
well pumped 1500 gpm with 51' drawdown at last reading		
we developed it quite a bit more but air line plugged (pinned off) and could not get more readings		
added 60 yds gravel 34 1/2'		
Cut off 10" of 10" thin leaves casing 1 ft above ground.		

### (13) PUMP:

Manufacturer's Name Layne & Bowler  
Type: Globe H.P. 50

### Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Mike Schneider Equip Co  
(Person, firm or corporation) (Type or print)

Address Star Route Box 97 St Paul Or

Drilling Machine Operator's License No. 301

[Signed] Mike Schneider  
(Water Well Contractor)

Contractor's License No. 387 Date 8-24-63

(USE ADDITIONAL SHEETS IF NECESSARY)