

RECEIVED
OCT 21 1964
MAR 21 1964
13503

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

WATER WELL REPORT

STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

STATE OF OREGON
(Please type or print)

State Well No. 9/1W-4 (E) ba
State Permit No. G-5345, G-8321

(1) OWNER:

Name ANTON MACK
Address Rt. 1 - Box 85 Aumsville ORE.

(2) LOCATION OF WELL:

County Marion Driller's well number
1/4 1/4 Section N.W. 4 T. 9.S. R. 1 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used

Size of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name Model No.
Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal
Depth of seal ft. Was a packer used?
Diameter of well bore to bottom of seal in.
Were any loose strata cemented off? Yes No Depth
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel:
Gravel placed from ft. to ft.
Did any strata contain unusable water? Yes No
Type of water? depth of strata
Method of sealing strata off

(10) WATER LEVELS:

Static level 0 ft. below land surface Date
Artesian pressure 12 lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " " "
" " " " "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow 75 g.p.m. Date 9/17/64
Temperature of water Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing 8

Depth drilled 262 ft. Depth of completed well 262 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
BLUE CLAY STONE	140	167
BROWN DECOMPOSED BASALT	167	183
Brown + Black - Firm	183	237
DECOMPOSED BASALT		
SHALY BLACK BASALT	237	262
CASING AND STRONG FLOW OF WATER AT 260'		
196' OF 8" 3/8 WALL CASING INSTALLED FROM + 1' TO 196'		
TOP 100 FT. OF CASING CEMENTED TO WALL OF 10" CASING WHICH IS PERFORATED		
WELL WAS CEMENTED BY HALIBURTON PROCESS		

Work started 7/1/64 19 Completed 9/18/64 19
Date well drilling machine moved off of well 9/33/64 19

(13) PUMP:

Manufacturer's Name
Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME MILLER - ROBINSON - WEST
(Person, firm or corporation) (Type or print)

Address 5345 Joseph St. S.E.

Drilling Machine Operator's License No. 59

[Signed] Hudson R. Miller
(Water Well Contractor)

Contractor's License No. 37 Date 9/28/64, 19.....