NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
SEP - 2 1975
WATER RESOURCES DEPT.
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON

(Please type or print)
(Do not write above this line)

13537

State Well No. 9S/1W-5
State Permit No. MARION

(1) OWNER:
Name MARIE GLUNN
Address Rt. 1 Box 104
AUMSVILLE, ORE

(2) TYPE OF WORK (check):
New Well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary ☐ Driven ☐
Cable ☒ Jetted ☐
Dug ☐ Bored ☐

(4) PROPOSED USE (check):
Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(5) CASING INSTALLED: Threaded ☐ Welded ☒
6" Diam. from 0 ft. to 35 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(6) PERFORATIONS: Perforated? ☒ Yes ☐ No.
Type of perforator used Torch
Size of perforations 3/16 in. by 5 in.
20 perforations from 25 ft. to 28 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? ☐ Yes ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes ☒ No If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "
Bailer test 15 gal./min. with 18 ft. drawdown after 2 hrs.
Artesian flow g.p.m.
Temperature of water 52° Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Portland cement
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 10 in.
Diameter of well bore below seal 6 in.
Number of sacks of cement used in well seal 4 sacks
Number of sacks of bentonite used in well seal sacks
Brand name of bentonite
Number of pounds of bentonite per 100 gallons of water lbs./100 gals.
Was a drive shoe used? ☐ Yes ☐ No Plugs Size: location ft.
Did any strata contain unusable water? ☐ Yes ☒ No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? ☐ Yes ☒ No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Driller's well number 96
SE ¼ SE ¼ Section 5 T. 9S R. 1W W.M.
Bearing and distance from section or subdivision corner
17' EAST of house

(11) WATER LEVEL: Completed well.
Depth at which water was first found 15 ft.
Static level 6 ft. below land surface. Date 7/25/75
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing
Depth drilled 35 ft. Depth of completed well 35 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
BROWN Soil & med GRAVEL	0	3	
BROWN Soil & large GRAVEL	3	22	
LARGE GRAVEL & SAND	22	35	

Work started 7/24 19 75 Completed 7/25/75 19
Date well drilling machine moved off of well 7/25/75 19

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Pat Kiddern (Drilling Machine Operator) Date 7/25/75 19
Drilling Machine Operator's License No. 898

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name FRANK WAGY WELL DRILLING (Person, firm or corporation) (Type or print)
Address 2435 Pine Lane ALBANY ORE
[Signed] Frank Wagy (Water Well Contractor)
Contractor's License No. 423 Date 8-25-, 19 75

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119