

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON within 30 days from the date of well completion.

RECEIVED WATER WELL REPORT JUL 1 1966 STATE OF OREGON (Please type or print) G-3558

MR. R. ... 13628

State Well No. 9/16-11L(3) State Permit No.

(1) OWNER:

Name Richard Schotthoefer Address 1520 E. Jefferson St. Stayton, Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number 177 NW 1/4 SW 1/4 Section 11 T9S R. 1W W.M. Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

New Well [x] Deepening [] Reconditioning [] Abandon [] Abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic [] Industrial [] Municipal [] Irrigation [x] Test Well [] Other [] Rotary [] Driven [] Cable [x] Jetted [] Dug [] Bored []

(5) TYPE OF WELL:

(6) CASING INSTALLED:

8" Diam. from 0 ft. to 50 ft. Gage .250

(7) PERFORATIONS:

Perforated? [x] Yes [] No Type of perforator used Acet. Torch - Mills Size of perforations 1/2 in. by 2 in. (1-1/2) 20 perforations from 50 ft. to 45 ft. (1-2) 250 perforations from 45 ft. to 20 ft.

(8) SCREENS:

Well screen installed? [] Yes [x] No Manufacturer's Name Model No. Diam. Slot size Set from ft. to ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite Depth of seal 20 ft. Was a packer used? no Diameter of well bore to bottom of seal 8 in. Were any loose strata cemented off? [] Yes [x] No Depth Was a drive shoe used? [x] Yes [] No Was well gravel packed? [] Yes [x] No Size of gravel: Gravel placed from ft. to ft. Did any strata contain unusable water? [] Yes [x] No Type of water? depth of strata Method of sealing strata off

(10) WATER LEVELS:

Static level 15 ft. below land surface Date 6/13/66 Artesian pressure lbs. per square inch Date

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level Was a pump test made? [x] Yes [] No If yes, by whom? Self Yield: 20 gal./min. with 5 ft. drawdown after 1 hrs. Bailer test 40 gal./min. with 20 ft. drawdown after 1 hrs. Artesian flow g.p.m. Date Temperature of water Was a chemical analysis made? [] Yes [] No

(12) WELL LOG:

Diameter of well below casing Depth drilled 50 ft. Depth of completed well 50 ft. Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include Top soil, Gravel-cobbles & claym, Cemented gravel, Clay gravel & cobbles, Cemented gravel cobbles, Sand - gravel (loose), Cement gravel - boulders, Silted gravel, Cement gravel, Clay - gravel (large cobbles).

Work started 6/8/66 19 Completed 6/13/66 19 Date well drilling machine moved off of well 6/13/66 19

(13) PUMP:

Manufacturer's Name Type: H.P.

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Pete Tolmasoff Well Drilling (Person, firm or corporation) (Type or print) Address Turner, Ore.

Drilling Machine Operator's License No. 320

[Signed] Pete J. Tolmasoff (Water Well Contractor)

Contractor's License No. 410 Date 6/20/66, 19