ORIGINAL
File Original, and Duplicate with the STATE ENGINEER, SALEM, OREGON

RECEIVED OCT 14 1957 STATE ENGINEER SALEM, OREGON

WATER WELL DRILLERS REPORT
STATE OF OREGON

Do Not Fill In

State Well No. 9/1W-15A

State Permit No. G173

MYR 13069

(1) OWNER:
Name TOWN OF STAYTON
Address Box 325 Stayton, Oregon

(2) LOCATION OF WELL:
County Marion Owner's number, if any—
R. F. D. or Street No.
Bearing and distance from section or subdivision corner
1360 feet East and 500 feet South of the ¼ corner between 10-15

(3) TYPE OF WORK (check):
New well ☒ Deepening ☐ Reconditioning ☐ Abandon ☐
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic ☐ Industrial ☐ Municipal ☒
Irrigation ☐ Test Well ☐ Other ☐

(5) EQUIPMENT:
Rotary ☐
Cable ☐
Dug Well ☒

(6) CASING INSTALLED:
Threaded ☐ Welded ☒

FROM	ft. to	ft.	Diam.	Gage or Wall
Top	"	23	60"	10
100' 24" cor. galv.				"
24" Ga. Infiltration line				"
"	"	"	"	"
"	"	"	"	"

Type and size of shoe or well ring
Describe joint

If gravel packed

Diameter of Bore	from ft.	to ft.
	"	"
	"	"
	"	"
	"	"
	"	"

Size of gravel:

(7) PERFORATIONS:
Type of perforator used punched
SIZE of perforations 3/8 to 1/2 in., length, by 3" O.D. in.

FROM	ft. to	ft.	perf per foot	No. of rows
In lower 1/3 of 100' 24" Infiltration line with perforations on inside rings.				
"	"	"	" " "	" " "
"	"	"	" " "	" " "

SCREENS: No Screens
Give Manufacturer's Name, Model No. and Size

(8) CONSTRUCTION:
Was a surface sanitary seal provided? ☒ Yes ☒ No To what depth ft.
Were any strata sealed against pollution? ☐ Yes ☒ No
If yes, note depth of strata

FROM	ft. to	ft.
"	"	"

METHOD OF SEALING

(9) WATER LEVELS:
Depth at which water was first found 6 ft.
Standing level before perforating 6 ft.
Standing level after perforating ft.

Log Accepted by:
[Signed] Town of Stayton (Owner) Dated 12-21-56, 19
By G. R. Bostwick City Engineer

(10) WELL TESTS:
Was a pump test made? ☒ Yes ☐ No If yes, by whom? H. Denherder
Yield: 3600 gal./min. with 4 ft. draw down after 120 hrs.
continous " " "
" " " "
Artesian flow none g.p.m.
Shut-in pressure lbs. per square inch.
Bailer test g.p.m. with ft. drawdown
Temperature of water Was a chemical analysis made? ☐ Yes ☐ No
Was electric log made of well? ☐ Yes ☒ No

(11) WELL LOG:
Diameter of well 60" inches.
Total depth 23 ft. Depth of completed well 23 ft.
Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

ft. to	ft.	
0	23	sand & gravel
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	Note : dug with power shovel
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	
"	"	

Ground elevation at well site 440 + or - feet above mean sea level.
Work started July 19 56 Completed November 20 19 56

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME G. R. Bostwick City Engineer
(Person, firm, or corporation) (Typed or printed)
Address Masonic Bldg Salem
Driller's well number
[Signed] G. R. Bostwick Civil Engineer (Well Driller)
License No. Eng #1780 Dated 12-21-56, 19