

NOTICE TO WATER WELL CONTRACTOR
 The original and first copy
 of this report are to be
 filed with the

STATE ENGINEER, SALEM, OREGON 97310
 within 30 days from the date
 of well completion.

owner: John + Abby
 Sigler

WATER WELL REPORT
 STATE OF OREGON
 STATE ENGINEER
 SALEM, OREGON

RECEIVED
 MAR 13 1974
 FEB 12 1974
 State Well No. 45/20-34
 State Permit No. _____

(Do not write above this line)

(1) OWNER:

Name Gene Koffler
 Address 1945 E. Hardcastle Road
Woodburn, Oregon

(2) TYPE OF WORK (check):

New Well Deepening Reconditioning Abandon
 If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:

Rotary Driven
 Cable Jetted
 Dug Bored

(4) PROPOSED USE (check):

Domestic Industrial Municipal
 Irrigation Test Well Other

(5) CASING INSTALLED:

Threaded Welded
 6" Diam. from top ft. to 156 ft. Gage 250
 " Diam. from ft. to ft. Gage
 " Diam. from ft. to ft. Gage

(6) PERFORATIONS:

Perforated? Yes No.
 Type of perforator used _____
 Size of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

(7) SCREENS:

Well screen installed? Yes No
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. Slot size Set from ft. to ft.
 Diam. Slot size Set from ft. to ft.

(8) WELL TESTS:

Drawdown is amount water level is lowered below static level
 Was a pump test made? Yes No If yes, by whom?
 Yield: gal./min. with ft. drawdown after hrs.
 " " " " " "
 " " " " " "
 Bailer test 30 gal./min. with 10 ft. drawdown after 1 hrs.
 Artesian flow g.p.m.
 Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:

Well seal—Material used Cement
 Well sealed from land surface to 20 ft.
 Diameter of well bore to bottom of seal 10 in.
 Diameter of well bore below seal 6 in.
 Number of sacks of cement used in well seal 7 sacks
 Number of sacks of bentonite used in well seal _____ sacks
 Brand name of bentonite _____
 Number of pounds of bentonite per 100 gallons
 of water _____ lbs./100 gals.
 Was a drive shoe used? Yes No Plugs _____ Size: location _____ ft.
 Did any strata contain unusable water? Yes No
 Type of water? _____ depth of strata _____
 Method of sealing strata off _____
 Was well gravel packed? Yes No Size of gravel: _____
 Gravel placed from _____ ft. to _____ ft.

(10) LOCATION OF WELL:

County Marion Driller's well number 1805
 ¼ ¼ Section 34 T. 4S R. 2W W.M.
 Bearing and distance from section or subdivision corner _____

(11) WATER LEVEL: Completed well.

Depth at which water was first found 93 ft.
 Static level 25 ft. below land surface. Date 2-4-74
 Artesian pressure _____ lbs. per square inch. Date _____

(12) WELL LOG:

Diameter of well below casing _____
 Depth drilled 165 ft. Depth of completed well 165 ft.

Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. Report each change in position of Static Water Level and indicate principal water-bearing strata.

MATERIAL	From	To	SWL
top Soil	0	2	
Yellow Clay	2	45	
Blue Clay	45	93	
Black sand	93	128	
Blue Clay	128	164	
Black sand	164	165	

Work started 1-22-74 19 Completed 2-4-74 19
 Date well drilling machine moved off of well 2-4-74 19

Drilling Machine Operator's Certification:

This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
 [Signed] Ronald Mottin Date 2-6-74 19
 (Drilling Machine Operator)
 Drilling Machine Operator's License No. 536

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
 Name WILLAMETTE DRILLING COMPANY
 (Person, firm or corporation) (Type or print)
 Address 7641 35th Ave. NE, Salem, Oregon
 [Signed] Emil O. Beier
 (Water Well Contractor)
 Contractor's License No. 2 Date 2-6-74 19