

RECEIVED

MAR 19 1961

137491

9/11W-18R

File Original and First Copy with the STATE ENGINEER, SALEM, OREGON

OCT 19 1961 WATER WELL REPORT

STATE ENGINEER STATE OF OREGON

G 2143

State Well No.

State Permit No.

(1) OWNER: SALEM, OREGON
Name Raymond Shrock
Address Route 1, Box 125
Aumsville, Oregon

(2) LOCATION OF WELL:
County Marion Owner's number, if any--
S E 1/4 S E 1/4 Section 18 T. 9 S R. 1 W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):
New Well [x] Deepening [] Reconditioning [] Abandon []
If abandonment, describe material and procedure in Item 11.

(4) PROPOSED USE (check):
Domestic [] Industrial [] Municipal []
Irrigation [x] Test Well [] Other []
(5) TYPE OF WELL:
Rotary [] Driven []
Cable [x] Jetted []
Dug [] Bored []

(6) CASING INSTALLED:
8" Diam. from 0 ft. to 22 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

(7) PERFORATIONS:
Type of perforator used cutting torch
Perforated? [x] Yes [] No
SIZE of perforations 1/2 in. by 6 in.
42 perforations from 11 ft. to 22 ft.

(8) SCREENS:
Well screen installed [] Yes [x] No
Manufacturer's Name
Type Model No.
Slot size Set from ft. to ft.

(9) CONSTRUCTION:
Was well gravel packed? [] Yes [x] No Size of gravel:
Gravel placed from ft. to ft.
Was a surface seal provided? [x] Yes [] No To what depth? 5 ft.
Material used in seal-- Sand and mud from well
Did any strata contain unusable water? [] Yes [x] No
Type of water? Depth of strata
Method of sealing strata off

(10) WATER LEVELS:
Static level 10 ft. below land surface Date 10/17/61
Artesian pressure lbs. per square inch Date

Log Accepted by:
[Signed] Mr. Raymond Shrock Date Oct 17, 1961 (Owner)

(11) WELL TESTS:
Drawdown is amount water level is lowered below static level
Was a pump test made? [x] Yes [] No If yes, by whom? owner
Yield: 100 gal./min. with 3 1/2 ft. drawdown after 2 hrs.

(12) WELL LOG:
Diameter of well 8 inches.
Depth drilled 22 1/2 ft. Depth of completed well 22 1/2 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

Table with columns MATERIAL, FROM, TO. Rows include: Brown sandy clay (0-5), Unconsolidated sand and gravel to boulder size--considerable brown silt (5-16), Partly cemented sand, gravel and clay (16-22'6")

Work started 10/15 1961. Completed 10/17 1961

(13) PUMP:
Manufacturer's Name
Type: H.P.

Well Driller's Statement:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME West Well Drilling (Person, firm, or corporation) (Type or print)

Address 4098 Market St., N.E., Salem

Driller's well number 61-21

[Signed] Marion C. West (Well Driller)

License No. 30 Date 10/17, 1961