NOTICE TO WATER WELL CONTRACTOR
The original and first copy of this report are to be filed with the
STATE ENGINEER, SALEM, OREGON 97310
within 30 days from the date of well completion.

RECEIVED
JUN 21 1971
STATE ENGINEER
SALEM, OREGON

WATER WELL REPORT
STATE OF OREGON
(Please type or print)
(Do not write above this line)

1384 MTR.....
G6028

State Well No. 9/1W-20bd
State Permit No.

(1) OWNER:
Name DORSEY GRAY
Address RT.1 BOX 132
AUMISVILLE, OREGON

(2) TYPE OF WORK (check):
New Well [X] Deepening [ ] Reconditioning [ ] Abandon [ ]
If abandonment, describe material and procedure in Item 12.

(3) TYPE OF WELL:
Rotary [ ] Driven [ ]
Cable [X] Jetted [ ]
Dug [ ] Bored [ ]

(4) PROPOSED USE (check):
Domestic [X] Industrial [ ] Municipal [ ]
Irrigation [ ] Test Well [ ] Other [ ]

CASING INSTALLED: Threaded [ ] Welded [X]
12" Diam. from 0 ft. to 31 ft. Gage .250
" Diam. from ft. to ft. Gage
" Diam. from ft. to ft. Gage

PERFORATIONS: Perforated? [X] Yes [ ] No.
Type of perforator used MILLS
Size of perforations 3 in. by 1/4 in.
80 perforations from 20 ft. to 30 ft.
perforations from ft. to ft.
perforations from ft. to ft.

(7) SCREENS: Well screen installed? [ ] Yes [X] No
Manufacturer's Name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

(8) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? [X] Yes [ ] No If yes, by whom?
Yield: 100 gal./min. with 1 ft. drawdown after 1 hrs.
200 " 1 " 1 "
" 500 " 1 " 1 "
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m.
Temperature of water Depth artesian flow encountered ft.

(9) CONSTRUCTION:
Well seal—Material used Bentonite
Well sealed from land surface to 18 ft.
Diameter of well bore to bottom of seal 14 in.
Diameter of well bore below seal 12 in.
Number of sacks of cement used in well seal none sacks
Number of sacks of bentonite used in well seal 1 sacks
Brand name of bentonite national
Number of pounds of bentonite per 100 gallons of water app. 50 lbs./100 gals.
Was a drive shoe used? [X] Yes [ ] No Plugs Size: location ft.
Did any strata contain unusable water? [ ] Yes [X] No
Type of water? depth of strata
Method of sealing strata off
Was well gravel packed? [X] Yes [ ] No Size of gravel:
Gravel placed from ft. to ft.

(10) LOCATION OF WELL:
County Marion Driller's well number
SE 1/4 NW 1/4 Section 20 T. 9S R. 1W W.M.
Bearing and distance from section or subdivision corner

(11) WATER LEVEL: Completed well.
Depth at which water was first found 15 ft.
Static level 9 ft. below land surface. Date 6/14/71
Artesian pressure lbs. per square inch. Date

(12) WELL LOG: Diameter of well below casing 12
Depth drilled 31 ft. Depth of completed well 31 ft.
Formation: Describe color, texture, grain size and structure of materials; and show thickness and nature of each stratum and aquifer penetrated, with at least one entry for each change of formation. *Report each change in position of Static Water Level and indicate principal water-bearing strata.*

MATERIAL	From	To	SWL
Gravel & Sand Brown	0	15	
Gravel & Sand	15	31	9

Work started 6/9/ 19 71 Completed 6/15 19 71
Date well drilling machine moved off of well 6/16 19 71

Drilling Machine Operator's Certification:
This well was constructed under my direct supervision. Materials used and information reported above are true to my best knowledge and belief.
[Signed] Robert P. Ehr (Drilling Machine Operator) Date 6/16, 19 71
Drilling Machine Operator's License No. 668

Water Well Contractor's Certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Name DUFFIELD BROS. WATER WELLS Inc. (Person, firm or corporation) (Type or print)
Address 1002 DIANNE DR. SE. SALEM, ORE.
[Signed] Leonard Duffield (Water Well Contractor)
Contractor's License No. 15 Date 6/16/ 19 71

(USE ADDITIONAL SHEETS IF NECESSARY)

SP*45656-119