

NOTICE TO WATER WELL CONTRACTOR

The original and first copy of this report are to be filed with the

STATE ENGINEER, SALEM, OREGON 97310 within 30 days from the date of well completion.

WATER WELL REPORT

STATE OF OREGON (Please type or print)

State Well No. 9/2w-4K

State Permit No. _____

MAR1.....
13928
MAR1

AUG 1964

(1) OWNER:

Name Ollie Runions
Address Rte. 1, Turner, Ore.

(2) LOCATION OF WELL:

County Marion Driller's well number 65
NW 1/4 SE 1/4 Section 4 T. 9S R. 2W W.M.
Bearing and distance from section or subdivision corner

(3) TYPE OF WORK (check):

Well Deepening Reconditioning Abandon
abandonment, describe material and procedure in Item 12.

(4) PROPOSED USE (check):

Domestic Industrial Municipal
Irrigation Test Well Other

(5) TYPE OF WELL:

Rotary Driven
Cable Jetted
Dug Bored

(6) CASING INSTALLED:

Threaded Welded

10" Diam. from 0 ft. to 66 ft. Gage .250
" Diam. from _____ ft. to _____ ft. Gage _____
" Diam. from _____ ft. to _____ ft. Gage _____

(7) PERFORATIONS:

Perforated? Yes No

Type of perforator used Acet. Torch - Mills
Size of perforations 1/4 in. by 8 & 2 in.
8" - 20 perforations from 64 ft. to 57 ft.
2" - 350 perforations from 57 ft. to 40 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

(8) SCREENS:

Well screen installed? Yes No

Manufacturer's Name _____ Model No. _____
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

(9) CONSTRUCTION:

Well seal—Material used in seal Bentonite
Depth of seal 20 ft. Was a packer used? no
Diameter of well bore to bottom of seal 10 in.
Were any loose strata cemented off? Yes No Depth _____
Was a drive shoe used? Yes No
Was well gravel packed? Yes No Size of gravel: _____
Gravel placed from _____ ft. to _____ ft.
Did any strata contain unusable water? Yes No
Type of water? _____ depth of strata _____
Method of sealing strata off _____

(10) WATER LEVELS:

Static level 8 ft. below land surface Date 7/28/64
Artesian pressure _____ lbs. per square inch Date _____

(11) WELL TESTS:

Drawdown is amount water level is lowered below static level

Was a pump test made? Yes No If yes, by whom? Ollie Runion
Yield: 125 gal./min. with 10 ft. drawdown after 6 hrs.
"This pump test made with" shallow-
"well pump" " " "
Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water 52 Was a chemical analysis made? Yes No

(12) WELL LOG:

Diameter of well below casing _____

Depth drilled 66 ft. Depth of completed well 66 ft.

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
Top-soil	0'	3'
Cobbles & clay	3'	9'
Cemented cobbles & gravel	9'	14'
Sand & clay	14'	18'
Cemented cobbles & clay	18'	25'
Large cobbles & clay	25'	26'
Tight packed sand & gravel	26'	37'
Sand & gravel (silted)	37'	50'
Course sand & gravel	50'	57'
Small cobbles - course sand		
clean & loose packed - Ideal	57'	66'
water-brg. formation		

Work started 7/17/64 Completed 7/28/64 19
Date well drilling machine moved off of well 7/29/64 19

(13) PUMP:

Manufacturer's Name _____
Type: _____ H.P. _____

Water Well Contractor's Certification:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Pete Tolmasoff Well Drilling
(Person, firm or corporation) (Type or print)
Address Turner, Ore.

Drilling Machine Operator's License No. 320

[Signed] Pete J. Tolmasoff
(Water Well Contractor)

Contractor's License No. 410 Date 8/4/64, 19____